

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/Indl./2020/SZ/ 08

Dated: 9/11/20

**FIRE SAFETY CERTIFICATE**

Certified that the M/s **SMS Exports** at Plot No W-7, Okhla Industrial Area, Phase-II, New Delhi-110020, comprised of **Basement, Ground plus one upper floor** was issued FSC by this department vide letter No. F.6/DFS/MS/Indl./2016/SZ/948 dated 07/06/2016. The premise was re-inspected by the officer concerned of this department on 26/12/2019 in the presence of Mr. Ajay Shani (Partner) and found to have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-G "Industrial"** with effect from 9/11/20 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 09/11 /2020 at New Delhi by

  
**(Rajesh Panwar)**  
**Dy. Chief Fire Officer**  
**Ph: 011-26189168**

Copy to: -

1. The Authorized Signatory M/s **SMS Exports** situated at Plot No W-7, Okhla Industrial Area, Phase-II, New Delhi-110020
2. The Ex. Engineer (Bldg.), Building Department, South MCD, Dr. SPM Civic Centre, Minto Road, New Delhi-110002

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

## INSPECTION REPORT

1	Name & Address of the Building	M/s SMS Exports at Plot No. W-7, Okhla Industrial Area, Phase-II, New Delhi-110020		
2	Type of Occupancy	Industrial (Group-G)		
3	Building Comprised of	Basement, Ground + One Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Indl./2016/SZ/948 dated 07/06/2016		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2013/1559 dated 11/06/2013		
7	Date of Inspection	26-12-2019		
8	Name of the Inspecting Officers	ADO (SJ) Mehmood		
9	Name & Designation of Officers from the building side	Mr. Ajay Shani (Partner)		
10	Year of construction	1982		
11	Applicant letter No.	Outdoor Diary No. 25598 dated 19-11-2019		
S. No.	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Requirement Old NOC</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building.</b>			
	• Road width	6m	Provided	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	Two	Provided	MR
	➤ Basement.	Two	Provided	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.25m	1.30m & 1.4m	MR
	➤ Basement	1.25m	1.30m & 1.5m	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	Required	One provided	MR
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	N/A	N/A	N/A
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust Fan	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
5	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	26 Nos	MR
	• Types		ABC, W.CO <sub>2</sub> & CO <sub>2</sub>	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	Battery backup	MR
	• Hooter's location	Required	Provided (Stairs)	MR

8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	150mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	One	Provided	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	One	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	Required	4 Nos	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	Required	4 Nos	MR
13	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	2280 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	60m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	Two	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	180 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	60m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	2280 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	60m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	900 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided	MR
14	<b>Captive water storage for fire-fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	1,00,000 Lts	1,00,000 Lts	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	20,000 Ltr	20,000 Ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
17	<b>Standby Power Supply</b>	Required	Provided	MR
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location</li> </ul>	N/A	N/A	N/A
19	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>Detector system panel.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Flow switch panel.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>PA system panel.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Battery backup.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Building floor plan.</li> </ul>	N/A	N/A	N/A
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Required	Two CO <sub>2</sub> type fire extinguisher provided	MR

The fire protection systems provided in the building/ premises were checked, tested at random and found functional at the time of inspection. The shortcoming communicated by this department vide letter no. F.6/DFS/MS/Indl./SZ/20194165 dated 12/07/19 found complied and the building is comprised of basement, ground and one upper floor only.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/Indl./2016/SZ/948 dated 07/06/2016, renewal under Rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Mehmood*  
2/1/20

Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

DO (SD)

*Mehra*  
02/01/2020

Dy cfo (S2)

what is the height of  
the building

*deep*  
2/1

DO(SD)



Sir as per fire safety guidelines issued dt. 11/06/2013 for bldg. Composition Basement, Ground Mezzanine and one upper floor, the height of the bldg. was 10.33 m (Pl. see C-13) Submitted Pt.

Dy cfo (S2)

*Mehra*  
03/01/2020

*deep*



*Mehra*  
06/01/2020

ADO (S2)

DO (S2)

*Mehmood*

