

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/2019/SZ/ 11

Dated: 13/01/2020

FIRE SAFETY CERTIFICATE

Certified that the Dr. B.R. Ambedkar Adarsh Vidyalaya located at ,Sec-5,Dakshin Puri, New Delhi-110062 comprised of ground floor only was issued NOC by this department vide letter No. F6/DFS/MS/School/SZ/2016/1225 Dated 29/11/2016. The premises was re-inspection by officer concerned by this department on 07/12/2019 in the presence of Mr. Lalit Kumar (Office) of the school and found that fire prevention and fire safety requirements have deemed complied in accordance with Circular No. 262-362 dated 17/01/2005 issued by Education Directorate, Govt. of NCT of Delhi, and that the premises fit for occupancy class Education Building, Group-B as above with effect from the date of issue of this certificate for period of three years subject to compliance of conditions mentioned below.

Issued on 13/01/2020 at New Delhi by

(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Principal, Dr. B.R. Ambedkar Adarsh Vidyalaya,Sec-5,Dakshin Puri, New Delhi-110062
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Dr. B.R. Ambedkar Adarsh Vidyalaya, Sec-5, Dhakshin Puri, New Delhi-110062		
2	Type of Occupancy	Educational "Group-B" (School)		
3	Building Comprised of	Ground Floor Only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/SZ/2016/1225 Dated 29/11/2016		
6	Fire Safety Directives Letter No	DOE Circular 262-362 dated 17/01/2015		
7	Date of Inspection	07/12/2019		
8	Name of the Inspecting Officers	Mehmood ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Lalit Singh (Office)		
10	Year of construction			
11	Applicant letter No.	F (3)GD/DRBRAAV/450/2019 dated 15/11/2019		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Accessible	6m	MR
	• Gate width	NA	02nos- 3.35m & 1.46m	NA
	• Width of internal road	N/A	N/A	NA
2	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	b) Width of Staircase		N/A	
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1mtr	1mtr	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	30 ACPH	NA	MR
	• Upper floors	12 ACPH	N/A	N/A
5.	Fire Extinguishers.			
	• Total numbers	03 No's	03No's	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A

7	Automatic fire detection & alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	N/A	N/A	N/A
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby pump head. Auto Starting/Manual Stopping. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	N/A	N/A	N/A
14.	Captive water storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provisions of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	N/A	N/A	N/A

9.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.			N/A
<p>The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.</p> <p>Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular 17/01/2005, FSC issued vide letter No F6/DFS/MS/School/SZ/2016/1225 Dated 29/11/2016 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
<p><i>Jameel</i> 12/12/19</p> <p>Signature of the Inspecting Officer Name: Mehmood Designation: ADO (SJ)</p>				

~~DO (SD)~~

Amir
12/12

DCFO (S2)

Amir
13/12

~~DO (SD)~~

Amir
13/12

ADO (SJ)

As per letter put up for signature please

Jameel
23/12/19

ADO (SJ)

~~CRICAD~~

DCFO (S2)

Amir
E1

