

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2019/SZ/ 25

Dated: 17/01/2020

FIRE SAFETY CERTIFICATE

Certified that M/s **Gastronomica Kitchen & Bar** (A unit of Delicious Concepts Pvt. Ltd) situated at M-55, M Block Market, Greater Kailash-I, New Delhi-110048, running at 2nd Floor of a building comprised of **basement, ground & two upper floors** was issued FSC in the name & style of M/s **KYC** (A unit of Yum Restaurants India Pvt. Ltd) by this department vide letter No. F.6/DFS/MS/2012/EH/3129 dated 29/08/2012. The said premise was re-inspected by the officer concerned of this department on 09/01/2019 in the presence of Sh. Subhash Goel of the restaurant and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly, Group-D**" (Restaurant) with effect from the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules-2010.

Issued on 17/01/2020 at New Delhi by


(Rajesh Panwar)
Dy. Chief Fire Officer
Tel. 011-26189168

Copy to: -

1. The Director M/s Delicious Concepts Pvt. Ltd at M-55, 2nd Floor, M Block Market, Greater Kailash-I, New Delhi-110048
2. The Dy. Health Officer, South Delhi Municipal Corporation, South Zone, Aurobindo Marg, Green Park, New Delhi-110016

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

