

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/Hospital/2020/SZ/ 46

Dated: ..... 16/01/2020

FIRE SAFETY CERTIFICATE

Certified that the **Holy Family Hospital, Okhla Road, New Delhi-110025**, comprised of Four Blocks namely Hospital Block ( Ground & 4 Upper Floors), OPD Block (Ground & 2 Upper Floors), Private OPD Block (Basement & Ground Floor) & Teaching Block (Ground & 2 Upper Floors) has already been issued FSC by this department vide letter no. F6/DFS/MS/Hospital/2017/SZ/244 dated 22/02/2017. The hospital was re-inspected by the officer concerned of this department on **09/01/2020** in the presence of **Mr. R.K Yadav (Security Officer)** and found that management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building fit for **Occupancy Group "C" Institutional (Hospital)** with effect from 16/01/2020 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16/01/2020 at New Delhi by

  
**Vipin Kental**  
Chief Fire Service  
Ph no.: 011-23412225  


Copy to:-

1. Father George P.A, Director, Holy Family Hospital, Okhla road, New Delhi-110025
2. The Executive Engineer (Building), SDMC, 8<sup>th</sup> Floor, Civic Center, Minto Road, New Delhi.

Conditions for the validity of fire safety certificate is as under

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate in form J, six month prior to its expiry.

