FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2020/ 60 **Dated:** 23/01/2020

FIRE SAFETY CERTIFICATE

Certified that **M/s Bikanervala Foods Pvt Ltd** Located at **Basement + Ground +1 Upper Floors A-28, Lawrance Road, Industrial Area Delhi-110035** in a building comprised of Basement + Ground +1 Upper Floors, was issued FSC vide Letter no. F6/DFS/MS/2006/1368Dated-21/06/2006, The premises was re inspected by the officers concerned of this department on 13-11-2019 in the presence of Mr. Puspander and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Industry" Group G with effect from 23/01/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/01/2020 at New Delhi by.

23/01/2020

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:

15/1/2020

1. M/s Bikanervala Foods Pvt Ltd, Located at A-28, Lawrance Road, Industrial Area Delhi-110035.
2. Dy. Health Officer, Karol Bagh Zone, NDMC, Public Health Department, Keshav puram Zone, New Delhi.
3. The Executive Engineer (Building), MCD Zone officer, Rajori Garden,(WZ) New Delhi.

Following fire safety directives must be adhered to:-

1. The FSC shall be null & void if 2nd floor/ tin shed is being used for any purpose.
2. The addition /alteration/ illegal construction if any shall be checked by building sectioning authority.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Basement shall be used as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The 2nd Floor shall not be reconstructed/use for any purpose.

INSPECTION REPORT

1. Name & address of the building: **M/s Bikanervala Foods Pvt. Ltd,** Located at**, A-28, Lawrance Road, Industrial Area Delhi-110035**
2. Type of Occupancy: Class –Industry **(Basement + Ground +1 Upper Floors & tin shed at terrace)**
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2006/1368Dated-21/06/2006
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/1996/242 Dated – 20/02/1996
6. Date of inspection : 13/11/2019
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer from the building side :Sh. Pushpander Singh (Manager HR)
9. Year of Construction :
10. Applicant's letter No. : Nil Dated -24/09/2019

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9mtrs	12m Provided	MR
	• Gate width	5m	370cm Provided	MR(Old Case)
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2x1.2m	1x92cm,1x140cm, 1x120cm	MR(Old Case)
	• Basements	2x1.2 m	1x140cm &1x117cm	MR(Old Case)
	c. Protection of exits			
	• Fire check door	Require	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	1 Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR(Old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12nos.	Provided	MR
	• Types	ABC & CO_2	provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 mtrs	provided	MR
	• Nozzle diameter	5mm	provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	Required	Provided	MR
	• Hose Box	Required	provided	MR
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➢ Head of main pump	NA	NA	NA
	➢ Number of main pumps	NA	NA	NA
	➢ Jockey pump out put	NA	NA	NA
	➢ Jockey pump head	NA	NA	NA
	➢ Standby Pump out put	NA	NA	NA
	➢ Standby Pump Head	NA	NA	NA
	➢ Auto Staring/Manual stopping	NA	NA	NA
	➢ Pump House Access	NA	NA	NA
	• Terrace level			
	➢ Discharge of pump	900 & 1320 lpm	Provided	MR
	➢ Head of the pump	40m	Provided	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	1,00000 ltrs	Provided	MR
	➢ Draw off connection	Required	Provided	MR
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	12500 ltrs	Provided	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➢ Pressurization of Lift Shaft	NA	NA	NA
	➢ Pressurization of lift lobby	NA	NA	NA
	➢ Communication in lift Car	NA	NA	NA
	➢ Fireman's Grounding Switch	NA	NA	NA
	➢ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	provided	MR
18.	Refuge Area			
	➢ Total area	NA	NA	NA
	➢ Location	NA	NA	NA
19.	Fire control room			
	➢ Detector system panel	NA	NA	NA
	➢ Flow Switch Panel	NA	NA	NA
	➢ PA System Panel	NA	NA	NA
	➢ Battery backup	NA	NA	NA
	➢ Building Floor Plans	Required	provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2006/1368Dated-21/06/2006 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note;- 1. The FSC shall be null & void if 2nd floor/ tin shed is being used for any purpose.

2. The addition /alteration/ illegal construction if any shall be checked by building sectioning authority.

Signature of the Inspecting Officer

Officer

Name Vidya Vir Singh

Designation ADO/WP

Signature of the Inspecting

Officer

Name

Designation

DO/W

21/11/14

Dy. FO/W2 whether the short comming have removed.