

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F6/DFS/MS/Bnqt/2020/NDZ/ 73

Dated: 28/1/2020

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Red Cherry Banquet Hall running on ground plus one upper floor of the building comprised of ground plus two upper floors located at A-2/3, Main Road Babarpur, Delhi-110032, owned/occupied by M/s Red Cherry Banquet Hall was issued Fire Safety Certificate vide letter No. F6/DFS/MS/2016/BNQT/NDZ/1656 dated 11/11/16. The banquet hall building was re-inspected by the officer concerned of this department in the presence of Sh. Anil Goyal (Owner) and found that the banquet hall have deemed complied with the fire prevention and fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and observed that the building is fit for occupancy class "D" 'Assembly Building' (Banquet Hall) with effect from 28/01/2020. for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....28/01/2020.....at New Delhi by



(Sunil Chawdhary)  
Dy. Chief Fire Officer

To,

Sh. Anil Goyal (Owner)  
M/s Red Cherry Banquet Hall  
A-2/3, Main Road Babarpur, Delhi-110032

Copy:-

The Dy. Health Officer  
EDMC, Public Health Department  
Shahdara (South) Zone, Karkardooma, Shahdara, Delhi-110032

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

