

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/2020/SZ/ 66

Dated: 28/01/2020

**FIRE SAFETY CERTIFICATE**

Certified that TDI Centre located at Plot No-7, District Centre, Jasola, New Delhi was granted NOC by this department vide letter no. F6/DFS/MS/2015/SZ/1351 dated 24/07/2015 for three tier basement, ground plus six upper floors. The building was re-inspected by the officers concerned of this department on 14/01/2020 in the presence of Mr. Manoj (Estate Manager) and found that the building management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Act-2007 & Rules-2010 and that the premises/building is fit for occupancy class- **Mixed (Mercantile & Business)** with effect from 28/01/20 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/01/2020 at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service  
R o/c

Copy to: -

1. The Authorized Signatory, TDI Centre, Plot No-7, District Centre, Jasola, New Delhi.
2. The Executive Engineer (Bldg.), S.D.M.C., Jal Vihar, Lajpat Nagar, New Delhi-110024

**Conditions for the validity of Fire Safety Certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
8. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

