

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/NDZ/2020/ 74


Dated: 28/01/2020

FIRE SAFETY CERTIFICATE

Certified that the V3S, East Centre Mall located at Plot No .12, Distt. Centre Laxmi Nagar, Delhi-110092, owned/occupied by M/s V3S Infratech Ltd., comprised of two basement, ground plus three upper floors was issued FSC vide letter No. F6/DFS/MS/2017/NDZ/77 dated 18/01/17. The Mercantile (Mixed occupancy) building was re-inspected by the team of officer of this department in the presence of Mr. Vineet Parasar, Manager and found that the Mercantile (Mixed occupancy) building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rules 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group F "Mercantile Building" with effect from ... 28/01/2020 for a period of **three** years, subject to conditions, printed below.

Note:- This certificate issued for existing building only and addition /alteration vide letter No. F6/DFS/MS/BP/2019/56 dated 8/12/2019 is yet to be constructed.

Issued on..... 28/01/2020 at New Delhi by


(Atul Garg)
Director

To,

Sh. Vineet Parashar
M/s V3S Infratech Ltd
A-20, Naraina Industrial Area,
Ph-1, New Delhi-110028

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

