

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F.6/DFS/MS/SZ/2020/ 77

Dated: 28/01/2020

**FIRE SAFETY CERTIFICATE**

Certified that M/s **IFFCO Sadan** located at C-1, District Centre, Saket, New Delhi-10017, comprised of Double Basement, Ground + 04 upper floors was issued SFC by this department officer by this department vide letter No. F.6/DFS/MS/2014/SZ/83 dated 20/01/2014. The said premise was re-inspected by officer concerned of this department on 28/12/2019 in the presence of Mr. Vijay Kr. Dhar (DGM, F&S) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for occupancy class "**Business Building**" with effect from 28/01/2020 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 28/01/2020 at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225

Copy to: -

1. Shri Ajay Pandey, Dy. General Manager (Estate), M/s Indian farmers Fertilizers Cooperative Limited (IFFCO Sadan), C-1, District Centre, Saket Palace, New Delhi-110017
2. The Dy. Director (Bldg.) C & I, DDA, Building Section, INA Vikas Sadan, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

