

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2020/SZ/ 32

Dated: 30/1/2020

**FIRE SAFETY CERTIFICATE**

Certified that **K.R. Manglam World School** located at S-Block, Greater Kailash-II, New Delhi-110048, having four interconnected wings/blocks each comprised of ground plus three upper floors (basement under one wing closed/sealed and undertaking submitted) was issued FSC by this department vide letter No.F.6/DFS/MS/School/2018/SZ/1462 dated 21/06/2018. The school building was re-inspection by officers concerned by this department on 14.01.2020 in the presence of Sh. YD Gupta (Chairman) and found the **Basement under one wing sealed by SDMC** and that building (**excluding basement**) have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from the date of issue of this certificate for period of **Three years** subject to compliance of conditions mentioned below.

Issued on 30/1/2020 at New Delhi by

  
(Atul Garg)  
Director

Tel: 011-23414000

Copy to: -

1. The Chairman M/s K.R. Manglam World School located at S-Block, Greater Kailash-II, New Delhi-110048
2. Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054
3. The Dy. Commissioner, SDMC, South Zone, Green Park, New Delhi - 16 - (To Check in r/o unauthorized construction, if any.)

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
7. This FSC is not valid for the basement and same shall not be used without prior permission of the competent/local authority.
8. The basement shall not be used for any purpose till it is regularized by SDMC.

