

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/EH/2020/NDZI/ 30

Dated 28/1/2020

FIRE SAFETY CERTIFICATE

Certified that the **Platinum Lounge Restaurant** running at shop no.G-17 ground floor of **Star City Mall**, plot no.1A, District Centre, Mayur Vihar-1, Delhi, comprised of basement, ground plus two upper floors owned/occupied by (A unit of True Blue Resto Bar Pvt. Ltd) was granted FSC vide letter No. F6/DFS/MS/EH/NDZ/2017/71 Dated 17/01/17. The Premises was re-inspected by the officer concerned of this department on 17/01/2020 in the presence of **Sh. Dharambir Singh** and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with the NBC Part-IV and is fit for occupancy class D“**Assembly Building**” (Restaurant) with effect from 28/1/2020.... for a period of **three** years, subject to conditions printed overleaf.

Issued on.....28/1/2020.....at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer

To

A unit of True Blue Resto Bar Pvt. Ltd,
Star City Mall, plot no.1A, District Centre,
Mayur Vihar-1, Delhi.

Copy to-

The Deputy Health Officer,
Shahdara (South) Zone, EDMC,
Health Department, Shahdara South Zone, Karkardooma, Delhi

Conditions

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This FSC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used as per BBL
8. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

