

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[Refer sub - rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No: F.6/DFS/MS/W2/School/60

Dated: 19/02/2020

**FIRE SAFETY CERTIFICATE**

Certified that the Capital Model School located at 36, Mukerjee Park, New Delhi-110018, comprised of Ground + Three upper floors only owned / occupied by Bhawna Educational Society (Regd.) has already been issued fire safety certificate vide letter no. F6/DFS/MS/School/2016/1855 dated 30/12/2016. The premises was re-inspected by the officer from this department on dated 11/02/2020 in the presence of Mrs. Meena (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with Director of Education Circular No. F6/Estate/CC/Fire/Safety/ 2011/3298-3398 dated 01/03/2011 and that the building / premises is fit for occupancy class "Educational" (Group-B) with effect from 19/02/2020 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/02/2020 at New Delhi.

  
(DHARAMPAL BHARDWAJ)  
DY. CHIEF FIRE OFFICER

Copy to:-

1. The Principal, Capital Model School, 36, Mukerjee Park, New Delhi-110018

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. There shall not be more than 45 students in class rooms in any case.

