

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2020/44

Dated: 19/02/2020

FIRE SAFETY CERTIFICATE

Certified that the **Daryaganj (A unit of Saaj Foods and Hospitality Pvt. Ltd.)** Located at Shop No. 11, 2nd Floor, Pacific Metro Mall Tagore Garden, Khayala, Subhash Nagar, New Delhi in a building comprised of Basement+ Ground + 4upper Floors owned/ occupied by **Daryaganj (A unit of Saaj Foods and Hospitality Pvt. Ltd.)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on **31/01/2020** in the presence of Mr. Ankush Myint (Employee) and found that the said building that the premises is fit for occupancy class "Assembly" Group D with effect from 19/02/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/02/2020 at New Delhi by.

(Rajesh Panwar)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Authorised Signatory, Daryaganj (A unit of Saaj Foods and Hospitality Pvt. Ltd.) at Shop No. 11, 2nd Floor, Pacific Metro Mall Tagore Garden, Khayala, Subhash Nagar, New Delhi

2. Dy. Health Officer (West Zone) South Municipal Corporation, Rajouri Garden, New Delhi

Following fire safety directives must be adhered to:-

1. **FSC is valid to run the restaurant on 2nd floor only**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. All the doors, Exits and internal roads must be kept free from any obstruction.
10. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **Daryaganj (A unit of Saaj Foods and Hospitality Pvt. Ltd.)** Located at **Shop No. 11, 2nd Floor, Pacific Metro Mall Tagore Garden, Khayala, Subhash Nagar, New Delhi**
2. Type of Occupancy : Assembly
3. Type of Case : *New*
4. Details of previous NO : Letter no. F6/DFS/MS/ 2017/WZ/577 dated 21/04/2017(FSC issue the Mall)
5. Fire Safety directives Letter No. : N.A.
6. Date of inspection : 31/01/2020
7. Name of the Inspecting Officer : Udai Vir Singh ADO (WP)
8. Name and designation of Officer
from the building side : **Mr. Ankush Myint (Employee)**
9. Year of Construction : 2011
10. Applicant's letter No. : 2020011101571 Dated 16/01/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	(Common for the Building)		
	• Road width	12 m	60 m Provided	MR
	• Gate width	5 m	Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits	(Common for the Building)		
	a. Number of staircases			
	• Upper floors	02	02 Provided for the Restaurant	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 staircase of 1.5 mtr width each	Provided	MR
	• Basements	For the Mall	For the Mall	For the Mall
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required for the restaurant	Provided	MR
	d. No of continuous staircase to terrace			
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1.5m	2x2.6m & 1x1.5m	MR

3.	Compartmentation	(Common for the Building)		
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	Provided	NA
	• Fire Rating of shaft door	NA	Provided	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	Provided	NA
4.	Smoke managements System	(Common for the Building)		
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10 for the restaurant	Provided	MR
	• Types	DCP & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system	(Common for the Building)		
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	3 rd floor at restaurant level	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required for the Mall	Provided	MR
10.	Automatic Sprinkler System:			
	• Basements	For the Mall	For the Mall	For the Mall
	• Upper Floor	Required for the restaurant	Provided	MR
	• Sprinkler above false ceiling	Required for the restaurant	Provided	MR
11.	Internal Hydrants:			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	01 for the restaurant	Provided	MR
	• Hose Box	01 for the restaurant	Provided	MR
12.	Yard Hydrants	Common with the mall		
	• Total number of hydrants	For the Mall	For the Mall	For the Mall
	• Hose Box	For the Mall	For the Mall	For the Mall

13.	Pumping Arrangements:	(Common for the Building)		
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 lpm 50 m Required Required	2850 lpm Provided 60 m Provided 02 Provided 180 lpm Provided 60 m Provided 2850 lpm Provided 60 m Provided Provided Provided 450 lpm Provided 50 m Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting: Common with the Building			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA NA NA NA 20, 000 ltrs	NA NA NA NA 20, 000 ltrs Provided	NA NA NA NA MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts:	For Building		
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N.R for the Restaurant		
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA NA	NA NA	NA NA
19.	Fire control room	Common with the Mall		
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA NA NA NA NA	Provided Provided Provided Provided Provided	NA NA NA NA NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2016/1414 dated 19/09/2016 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

1. The total covered area 169 m² (As per information received from Licensing Authority)
2. As per part IV, NBC-2016, table no 4.3 under clause 4.4.2.1 the occupant load for dining area and restaurant is 1.8. Accordingly the number of seats come out to be 94 (169/1.8=93.88 say 94) for whole restaurant.
3. The total seating capacity comes out be 94

Signature of the Inspecting Officer

Name

Designation

Uday Vir Singh
ADD LWP

Signature of the Inspecting Officer

Name

Designation

[Signature]

[Signature]

[Signature]

[Signature]

[Signature]

Directed

6/12/2020

[Signature]

bir ft letter is put up for sign

6/12/2020