

0/L.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**


No. F6/DFS/MS/School/2019/NDZ/ 59

Dated: 18/2/2020

FIRE SAFETY CERTIFICATE

Certified that the Shri Saraswati Vidya Niketan, at A-14/301, Brijpuri, Delhi-110094, comprised of ground plus first floor owned/occupied by Shri Saraswati Vidya Niketan have complied with the fire prevention and fire safety requirements in accordance with circular No-F-16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officers concerned of fire service on 08/11/2019 in presence of Dr. Shailender Kumar Gaur, Manager of the school and found that the school building is fit for occupancy class "B" 'Educational Building' for ground plus first floor with effect from 18/2/2020... for a period of three years, subject to conditions printed overleaf.

Issued on.....18/2/2020.....at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer

To,
The Principal,
Shri Saraswati Vidya Niketan,
A-14/301, Brijpuri,
Delhi-110094

Copy:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

