

0/L.

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2019/NDZ/ 59

Dated: 18/2/2020

FIRE SAFETY CERTIFICATE

Certified that the Shri Saraswati Vidya Niketan, at A-14/301, Brijpuri, Delhi-110094, comprised of ground plus first floor owned/occupied by Shri Saraswati Vidya Niketan have complied with the fire prevention and fire safety requirements in accordance with circular No-F-16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and verified by the officers concerned of fire service on 08/11/2019 in presence of Dr. Shailender Kumar Gaur, Manager of the school and found that the school building is fit for occupancy class "B" 'Educational Building' for ground plus first floor with effect from 18/2/2020... for a period of three years, subject to conditions printed overleaf.

Issued on.....18/2/2020.....at New Delhi by


(Sunil Chawdhary)
Dy. Chief Fire Officer

To,
The Principal,
Shri Saraswati Vidya Niketan,
A-14/301, Brijpuri,
Delhi-110094

Copy:-
The Dy. Director of Education,
B-Block, Yamuna Vihar,
Delhi-110053

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT


- | | |
|--|---|
| 1. Name & address of the building | : Shri Saraswati Vidya Niketan,
A-14/301, Brijpuri, Delhi-110094 |
| 2. Building is comprised of | : Ground plus first floors |
| 3. Type of Occupancy | : Educational |
| 4. Type of Case | : Renewal |
| 5. Details of Previous NOC letter | : F6/DFS/MS/2016/1349 dated-02/09/2016 |
| 6. Fire Safety direction letter No. | : F.16/Estate/CC/Fire safety/2011/3298 to
3398 dt- 01/03/2011 |
| 7. Date of Inspection | : 08/11/2019 |
| 8. Name of the Inspecting officers | : ADO Nagender Singh |
| 9. Name and designation of Officer
from the building side | : Dr. Shailender Kumar Gaur |
| 10. Year of Construction | : 2007 |
| 11. Applicant's letter No | : Letter No. nil, Dated- 27/09/2019 |


Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	As per Circular dated 01/03/2011	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06mtr.	4.56mtr.	MR(as old case)
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	01nos	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	1.50mtr	1.10mtr. each	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	04 nos.	04 nos.	MR
	• Types	ABC /CO ₂	ABC/ CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR


06	First-Aid-Hose Reels.			
	Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A



Keeping in view of the compliance of the minimum standards of fire prevention and fire safety required under the circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11, it is recommended to grant Fire Safety Certificate.


NAGENDER SINGH
Assistant Divisional Officer
(Shahdara)


DO(ED)


DY. C&A
F.T. please

DO(E)


ADO(Shahdara)
F.T. submitted please

20/11