

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE : NEW DELHI – 110001


No. F.6 / DFS / HQ / 2020 / 43

Dated. 19/02/2020

FIRE SAFETY CERTIFICATE

Certified that the M/s Spezia.Bistro (Aspen Enterprises) located at 2525, 1st floor Hudson Lane, Kingsway Camp, New Delhi - 110009 in the building comprised of Basement, Ground and 02 upper floors owned/occupied by M/s Spezia Bistro (Aspen Enterprises) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 15.12.2019 in the presence of Sh. Sanjay Verma and that the building/premise is fit for occupancy Class Assembly for first floor only with effect from 19/2/20 for a period of 03 (three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/2/20 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service
g/c

Copy to:- 1.

1. M/s Spezia Bistro (Aspen Enterprises) 2525, 1st floor, Hudson Lane, Kingsway Camp, Delhi - 110009.
2. The Dy. Health Officer, NDMC, Public Health Department City, S.P. Zone, Old Hindu College, Kashmere Gate, Delhi.
3. Addl. CP/Lic. Defence Colony, Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

2/16

INSPECTION REPORT

1. Name & address of the building :Spezia Bistro (Aspen Enterprises), 1st Floor, Hudson Lane, Kingsway Camp, Delhi-110009.
2. Type of Occupancy :Assembly (Restaurant at First floor in the building of b+g+02floor)
3. Type of Case :New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No :NBC Part IV(2005)
6. Date of inspection :15.12.2019
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Mr. Sanjay Verma
9. Year of Construction : 2015
10. Applicant's letter No. : 36904-11/Addl..CP/Lic./EH(DA-VIII) dated 04.11.2019

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m & 1.00m	1.50m & 1.10m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	NA	NA
f. Door Size	2.0m & 1.50m	2.00m x 02	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

AM

