

FIRE SAFETY CERTIFICATE

Certified that the CNG Filling Station(IGL) at Rohini , Sector-27, Delhi comprised of **Single Story Building** owned / occupied by **Indraprastha Gas Limited** was granted NOC by this department vide letter no **F6/DFS/MS/2016/CNG/WZ/449 Dated 21/03/2016**. The premises was re-inspected by officer concerned of this department on **17/01/2020** in the presence of **Mr. Ajay Khatri (Manrager)** and found that the premises have deemed complied with the fire prevention and fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and the building/ premises is fit for occupancy **CNG Filling Station Group 'J'** with effect from **19 / 02 / 2020** for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010 subject to conditions printed below.

Issued on **19/02/2020** at New Delhi by

(Dhrampal Bhardwaj)

Dy. Chief Fire Officer

Ph:- 011251567707

Copy to:

1. Chief General Manager (project), Indraprastha Gas Limited, IGL Bhawan, Plot no-4, Community Center, R.K. Puram, Sect-9, New Delhi-110022.
2. The Addl. Commissioner of Police (Lic), 1st Floor, Police Station, Defense Colony, Delhi

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use for land if any.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. **The conditions as mentioned in letter no F5/(3A)/DFS/CNG/BP/2010/269 dated 09/09/2010 shall be followed strictly.**
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The is available on

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station(IGL) at Rohini, Sector-27, Delhi
 2. Type of Occupancy : CNG Filling Station **Group "J"/ Business**
 3. Type of Case : Renewal
 4. Details of Previous NOC : F6/DFS/MS/2016/CNG/WZ/449 Dated 21/03/2016
 5. Fire Safety directives letter No : F5/(3A)/DFS/CNG/BP/2010/269 dated 09/09/2010
 6. Date of inspection : 08/12/2019
 7. Name of Inspecting Officer : A.K. Sharma
 8. Name and designation of officers
 From the building side : *Ajay Khatri (Manager)*
 : Mr. ~~Alok~~ Sharma (~~Vice President~~)
 9. Year of Construction : 2010
 10. Applicant's letter No. : IGL/F&S/2019/15/39/0, O.D No.18126 Dated 26/08/2019

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC /35(6) Requirement	Provided at site	Remarks MR/NMR
1.	Access to building[
	• Road width	Required	30 mtr	M/R
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.25 mtr	Provided	MR
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	N/A	NA	NA
	• Pressurization	N/A	NA	NA
	d. No. of continuous staircases to terrace	N/A	NA	NA
	e. Width of Corridor	N/A	NA	NA
	f. Door Size	1.0 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	NA	NA
	• Sealing of electrical shafts	N/A	NA	NA
	• Fire Rating of shaft door	N/A	NA	NA
	• Water Curtain	N/A	NA	NA
	• Fire Dampers	N/A	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	N/A	NA

CNG Filling Station (IGL) at Rohini, Sector-27, Delhi

N/12

	• Upper floors	12 a/c per hour	N/A	NA
5.	Fire Extinguishers			
	• Total numbers	7.5 Kg-02	Provided	MR
	• Types	10 Kg-07	DCP type	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	N/A	NA
	• Length of hose reel hose	30 m	N/A	NA
	• Nozzle diameter	5 mm	N/A	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
		N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA


M/13

	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump			
14.	Captive Water Storage for firefighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	Buckets filled with sand, No smoking board were found displayed in Hindi & English. No loose electric wiring were seen in premises & CO2 flooding system found provided		MR
21.	DCP spray system for cascade	Provided		MR

The fire protection systems provided in the building premises were test checked and found functional at the time of inspection.

in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the DFS rules of NOC issued vide letter no. F6/DFS/MS/2016/CNG/WZ/449 Dated 21/03/2016, renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.


Accordingly DFA is put up for approval for signature please



 Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

~~Do (aw)~~


 27/1/20

CNG Filling Station (IGL) at Rohini Sector-27, Delhi


 27/1/20


 27/1/20