

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2020/ 67

Dated : 28/01/2020

FIRE SAFETY CERTIFICATE

Certified that the **One 8 Commune (A Unit of V&T restaurant and bar Pvt. Ltd.)** located at **84, ground floor & Mezzanine Floor Janpath, New Delhi** comprises of **Ground, Mezzanine + 02 Upper floor, Restaurant is running at ground floor only & mezzanine floor (for store)**. The premises was inspected by the officer concerned of this department on **24/01/2020** in the presence of **Mr. Kamal Kumar** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building Group D, Restaurant at Ground floor only** with effect from ~~28/01/2020~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued ~~28/01/2020~~ at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Medical officer of Health,
Health Department, Palika Kendra, New Delhi
2. The Manager, **One 8 Commune (A Unit of V&T restaurant and bar Pvt. Ltd.)** located at **84, ground floor & Mezzanine. Floor Janpath, New Delhi**

Condition for the validity of fire safety certificate

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method
of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and lapse
rendering non functional of fire safety measures, management shall be responsible.
4. Any deviation with regard to construction, electric installation etc may be got verified from the concerned authorities.
5. Basement shall be used as per NBC / BBL 1983.
6. This NOC may not be treated in any case for regularizations of unauthorized construction if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of
Delhi fire service 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The access around the blocks as submitted in the plans submitted by Principal Architect Design Plus shall be kept clear of any obstruction for free movement of fire units in case of emergency.
9. The owner / occupier shall apply for renewal of this fire safety certificated to the director in Form 'the
[sub rule (1) of rule 37] along with a copy of this certificate, six months prior to it expiry.

