

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/EH/SZ/2020/50

Dated: 25/02/2020

FIRE SAFETY CERTIFICATE

Certified that the M/s. Burger King India Private Limited running at Ground Floor of a building comprised of basement, ground plus three upper floors located at GF, 13/29-30, Ajmal Khan Road, Karol Bagh, New Delhi-110005, owned/occupied by M/s Burger King India Private Limited. The restaurant was inspected by the officer concerned of this department on 21.01.2020 in presence of Sh. Vikas (Branch Manager) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (restaurant) at ground floor only with effect from 25/02/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 25/02/2020 at New Delhi by.



(Atul Garg)
Director
Delhi Fire Service

ole
h

Copy to:-

1. The Deputy Health Officer, North Delhi Municipal Corporation, Karol Bagh, Zone, Anand Parbat, New Delhi - 110005. As per the plan submitted vide letter No. DHO/KBZ/2019/2068 dated 01.01.2020.
2. The Addl. Commissioner of Police (Lic.), 1st floor, Police Station Defence Colony, New Delhi.
3. The Owner / Occupier, M/s Burger King India Private Limited, GF, 13/29-30, Ajmal Khan Road, Karol Bagh, New Delhi - 110005.

CONDITIONS

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

