

c-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / School/2020 / 71

Dated: 25/02/2020

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-Ed. Sr. Sec. School (ID-1310161) located at Village Barwala, Delhi-110039 comprised of **Ground and 01 upper floor** owned/occupied by Govt. Co-Ed. Sr. Sec. School was issued FSC by this department vide letter no. No.F6/DFS/MS/2017/School/80 dated 18.01.2017. The premises was re-inspected by the officer concerned of this department on 03.02.2020 in presence of **Sh. Ajab Singh Rana, Vice Principal** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **class Group B Educational** with effect from ...25/02/2020... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ...25/02/2020... at New Delhi by.


(Dharmpal Bhardwaj)
Dy.Chief Fire Officer
Ph:-011-25156707
DH

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi -54.
2. The Principal, Govt. Co-Ed. Sr. Sec. School, Barwala, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year in Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/7

INSPECTION REPORT

1. Name & address of the building :Govt. Co-Ed. Sr. Sec. School (ID-1310161), Barwala, Delhi-110039.
2. Type of Occupancy :Educational
3. Type of Case : Renewal (G+1 upper Floors)
4. Details of previous NOC : F6/DFS/MS/2017/School/80 dated: 18/01/2017
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection :03/02/2020
7. Name of the Inspecting Officers : ADO (RN)-
8. Name and designation of officers from the building side : Sh. Ajab Singh Rana (Vice Principal)
9. Year of Construction : 1995
10. Applicant's letter No. : Nil Diary No. 328 Dated: 06/01/2020

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR	
1	Access to building				
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Accessible	MR	
		Accessible	Accessible	MR	
		NA	NA	NA	
2	Number, Width, Type & Arrangement of Exits				
	a. Number of staircases				
		<ul style="list-style-type: none"> • Upper Floors • Basements 	02 NA	02 NA	MR NA
	b. Width of staircases				
		<ul style="list-style-type: none"> • Upper Floors • Basements 	1.50M NA	1.50m each NA	MR NA
	c. Protection of exits				
		<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA NA NA	NA NA NA	NA NA NA
		d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor				
	f. Door Size	1 m	1m	MR	
	3	Compartmentation.			
		<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door 	NA	NA	NA
			NA	NA	NA
			NA	NA	NA

