

c-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No F 6 / DFS / MS / School/2020 / 71

Dated: 25/02/2020

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Co-Ed. Sr. Sec. School (ID-1310161) located at Village Barwala, Delhi-110039 comprised of **Ground and 01 upper floor** owned/occupied by Govt. Co-Ed. Sr. Sec. School was issued FSC by this department vide letter no. No.F6/DFS/MS/2017/School/80 dated 18.01.2017. The premises was re-inspected by the officer concerned of this department on 03.02.2020 in presence of **Sh. Ajab Singh Rana, Vice Principal** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **class Group B Educational** with effect from ...25/02/2020... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ...25/02/2020... at New Delhi by.

  
(Dharmpal Bhardwaj)  
Dy.Chief Fire Officer  
Ph:-011-25156707  
ek

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi -54.
2. The Principal, Govt. Co-Ed. Sr. Sec. School, Barwala, Delhi-110039.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year in Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization ( Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

N/7

**INSPECTION REPORT**

1. Name & address of the building : Govt. Co-Ed. Sr. Sec. School (ID-1310161), Barwala, Delhi-110039.
2. Type of Occupancy : Educational
3. Type of Case : Renewal ( G+1 upper Floors)
4. Details of previous NOC : F6/DFS/MS/2017/School/80 dated: 18/01/2017
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 03/02/2020
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Sh. Ajab Singh Rana (Vice Principal)
9. Year of Construction : 1995
10. Applicant's letter No. : Nil Diary No. 328 Dated: 06/01/2020

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Accessible	Accessible	MR
		Accessible	Accessible	MR
		NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02 NA	02 NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	1.50M NA	1.50m each NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	NA NA NA	NA NA NA	NA NA NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor			
	f. Door Size	1 m	1m	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA

2/3

	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	08nos	15nos	MR
	• Types	ABC/Co2	ABC—15	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			



219

	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	NA	N/A	NA
	➤ Head of the pump	NA	N/A	NA
	➤ Power Supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	N/A	NA
15	<b>Exit Signage.</b>	NA	NA	NA
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A

N/A

	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A.	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.80 dated 18.01.2017.

1/14  
18/12/2020

Signature of the Inspecting Officer

Name: - Rajesh Kumar

Designation: - ADO/RN

DO / NWD - on leave

1/14/2020

14/12/2020

As approved, F.T. letter is put up for your signature or

1/14  
18/12/2020

1/14/2020

14/12/2020

not cell