

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / 2020 / 73

Dated: 25/02 /2020

FIRE SAFETY CERTIFICATE

Certified that the **Jesus Grace Modern School** located at **Gali No. 13-B,A-Block, Baba Colony, Burari, Delhi-110084** comprised of ground and 02 upper floors (School is running at ground & first floor) only owned/ occupied by the **Jesus Grace Modern School** was issued fire safety certificate vide this office letter no. **F.6/DFS/MS/School/2014/WZ/1397** dated **14/11/2014**. The premises was re-inspected by the officer concerned of this department on 10.02.2020 in presence of **Mr. Manoj Kumar, Manager** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational for ground and one upper floor only with effect from **25/02/2020** for a period of three years, subject to compliance of the conditions mentioned below:

Issued on **25/02/2020** at New Delhi by.

(Dharmपाल Bhardwaj)
Dy.Chief Fire Officer
Ph:-011-25156707

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Manager, Jesus Grace Modern School, Gali No. 13-B,A-Block, Baba Colony, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year in Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
- 7 This FSC is valid only for g+1 educational occupancy .The use of second floor is not allowed in any case violation will be treated as cancellation of FSC.

INSPECTION REPORT

- 1 Name & address of the building : Jesus Grace Modern School, Gali No. 13-B,A-Block, Baba Colony, Burari, Delhi-110084.
- 2.Type of Occupancy : Educational- Ground + 02(School is running on G+1floor)
- 3 Type of Case : Renewal
- 4 Details of previous NOC : F6/DFS/MS/School/2014/WZ/1397 Dated: 14.11.2014
- 5 Fire Safety directives letter No : Director of Education Letter dated 01.03.2011
- 6 Date of inspection : 10/02/2020
- 7 Name of the Inspecting Officers : ADO (RN)
- 8 Name and designation of officers
from the building side : Mr. Manoj Kumar/ Manager
9. Year of Construction : 2008/2016
10. Applicant's letter No. : Dairy No. 26904 dated 06.12.2019

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible)	MR
	• Gate width	Accessible	Accessible	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 m	1.25m & 91cm	MR(Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	1	1	MR
	e. Width of Corridor	NA	NA	NA
f. Door Size	1.0m	1m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

