

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2020 / 73

Dated: 25/02 /2020

FIRE SAFETY CERTIFICATE

Certified that the **Jesus Grace Modern School** located at **Gali No. 13-B,A-Block, Baba Colony, Burari, Delhi-110084** comprised of ground and 02 upper floors (School is running at ground & first floor) only owned/ occupied by the **Jesus Grace Modern School** was issued fire safety certificate vide this office letter no. **F.6/DFS/MS/School/2014/WZ/1397** dated **14/11/2014**. The premises was re-inspected by the officer concerned of this department on 10.02.2020 in presence of **Mr. Manoj Kumar, Manager** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational for ground and one upper floor only with effect from 25/02/2020 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 25/02/2020 at New Delhi by.


(Dharmpal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Manager, Jesus Grace Modern School, Gali No. 13-B,A-Block, Baba Colony, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
- 7 This FSC is valid only for g+1 educational occupancy .The use of second floor is not allowed in any case violation will be treated as cancellation of FSC.

INSPECTION REPORT

- 1 Name & address of the building : Jesus Grace Modern School, Gali No. 13-B,A-Block, Baba Colony, Burari, Delhi-110084.
- 2.Type of Occupancy : Educational- Ground + 02(School is running on G+1 floor)
- 3 Type of Case : Renewal
- 4 Details of previous NOC : F6/DFS/MS/School/2014/WZ/1397 Dated: 14.11.2014
- 5 Fire Safety directives letter No : Director of Education Letter dated 01.03.2011
- 6 Date of inspection : 10/02/2020
- 7 Name of the Inspecting Officers : ADO (RN)
- 8 Name and designation of officers
from the building side : Mr. Manoj Kumar/ Manager
9. Year of Construction : 2008/2016
10. Applicant's letter No. : Dairy No. 26904 dated 06.12.2019

| | Minimum Standards on fire prevention and fire safety U/R 33 | Dir. Of Education | Provided at site | Remarks MR/NMR |
|---|---|-------------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | Accessible | Accessible) | MR |
| | • Gate width | Accessible | Accessible | NA |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 01 | 02 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.50 m | 1.25m & 91cm | MR(Old Case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 1 | 1 | MR |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 1.0m | 1m | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |

| | | | | |
|----|---|-----------------|--------------------|----|
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | 30 a/c per hour | No basement | NA |
| | • Upper floors | 12 a/c per hour | Natural Ventilated | MR |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 5nos | 15 nos | MR |
| | • Types | ABC/Co2 | ABC- 15 | MR |
| | • ISI marking | Yes | Yes | MR |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7 | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |

| | | | | |
|----|---|-----|---|-----|
| | <ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump | | | |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | | | |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 14 | Captive Water Storage for fire fighting. | |
| | <ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection➤ Fire service inlet➤ Access to tank• Overhead Tank capacity | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 15 | Exit Signage. | NA | NA | NA |
| 16 | Provision of Lifts. | | | |
| | <ul style="list-style-type: none">• Pressurization of Lift Shaft• Pressurization of Lift lobby• Communication In lift Car• Fireman's Grounding Switch• Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 17 | Standby power supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | <ul style="list-style-type: none">➤ Total Area➤ Location | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | <ul style="list-style-type: none">• Detector System Panel• Flow Switch Panel | N/A | N/A | N/A |
| | | N/A | N/A | N/A |

| | | | | |
|----|--|-----|-----|-----|
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 01.03.2011 the FSC issued vide letter of even no 1397 dated 14.11.2014 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended

Signature of the Inspecting Officer

Name :- Rajesh Kumar

Designation:- ADO/RN

14/12/2020

Dy Cfo W2

14/12/2020

ADO/RN - F-T

As approved, f-t letter a pickup for your signature pl

14/12/2020

Dy Cfo W2

14/12/2020

ms/ cell