

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/GH/SZ/2020/ 75

Dated: 25/2/2020

FIRE SAFETY CERTIFICATE


Certified that **M/s The Exotica Grand guest house located at 1/12, West Patel Nagar, New Delhi-110008**, comprised of basement floor as Storage/ Hall, stilt floor for parking and reception, ground floor as waiting lobby and hall, first, second & third floor each having eleven guest rooms (Total 33 guest rooms) and one staff room & pantry for staff on terrace floor was issued FSC by this department vide letter no. F.6/DFS/MS/GH/SZ/2017/47 dated 12.01.2017. The guest house was re-inspected by the officer concerned of this department on 07.02.2020 in presence of Mr. Lal Babu, manager and found that the said guest house have removed pantry from terrace floor. The owner of the guest house has submitted affidavit for not to use any occupancy above third floor and have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class residential (guest house) **for basement floor as Storage/ Hall, stilt floor for parking and reception, ground floor as waiting lobby and hall, first, second & third floor each having eleven guest rooms (Total 33 guest rooms only) up to third floor** with effect from 25/2/20 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 25/2/20 at New Delhi.


24/2

(SS Tuli)

Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to: -

1. The Joint C.P..C.P (Lic.), Police Station,
Defence Colony, 1st floor, New Delhi
2. The Manager,
M/s The Exotica Grand guest house,
1/12, West Patel Nagar,
New Delhi-110008

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
9. Basement shall be used as per BBL.
10. No temporary shed is allowed on terrace.
11. The Fire Safety Certificate is only for Guest Rooms.
12. **The Gazette Notification of UBBL-2016 amendment inserted as clause No. 7.31 of Chapter- 7 by the Directorate of Local Bodies vide letter No. F. 5(189)/AD/LB/2016/4053-67 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/11940-55 dated 25.09.2019 & Letter No. F.5 (189)/AD/LB/2016/171-186 dated 27-12-2019 in respect of existing building (Copy enclosed) shall be implemented by 31.03.2020 under intimation to Delhi Fire Service and if the provisions are not made within the stipulated time then the FSC shall stand null & void.**