

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI**

No. F6/MS/DFS/NDZ/2018/ 04

Dated: 02.02.2019

**FIRE SAFETY CERTIFICATE**

Certified that M/s ITPO Halls No. 7A, B, C, D, E, F, G, H, 8, 9, 10, 11, 12 & 12A (Excluding first floor) located at Mathura Road, New Delhi, comprised of ground plus one upper floor, owned/occupied by International Trade Promotion Organizer was inspected by the officers concerned of this department on 20.12.2018 in the presence of Sh. Amit Chhikara and other officers of ITPO and found that the owner/occupier have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises (Ground floor only) is fit for occupancy Group-D, Assembly building with effect from 02.01.2019 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed as under.

Issued on 02.01.2019 at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer,  
Ph: 011 - 23412225.

Copy to:

1. Deputy General Manager International Trade Promotion Organizer, Mathura Road, New Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked and unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
9. Extra manpower be deployed towards digging side of halls to channelings the crowd.
10. In case of subdivision/change in layout it shall be referred to this department through concern licensing authority.

**INSPECTION REPORT**

1. Name & address of the building : ITPO Mathura Rd.
2. Building comprised of : G. + I<sup>st</sup> Floor
3. Type of Occupancy : Assembly D-6
4. Type of Case : New Case/ Renewal
5. Details of previous NOC : Letter No. NA Dated: 24-12-18
6. Fire Safety directives letter No : DFS/MS/BP/2008/2872 Dt 15/4/08
7. Date of inspection : 20-12-2018
8. Name of the Inspecting Officers : CFO ND2, DeFO ND2, ADOLCC,
9. Name and designation of officers from the building side : Fire Officer Amit Chhikar
9. Year of Construction : \_\_\_\_\_
10. Applicant's letter No. : \_\_\_\_\_

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	13 Mts.	13 Mts	MR
	• Gate width	5 Mts.	6 Mts.	MR
	• Width of internal road	6 Mts	9 Mts	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			/
	• Upper Floors			
	• Basements			
	b. Width of staircases			/
	• Upper Floors			
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			/
	g. Width of Corridor			
	h. Door Size			
3	<b>Compartmentation.</b>			
	• Fire check door			/
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			

2018

5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	ISI marked	280 ABC, w <sub>2</sub> w <sub>2</sub> R	360 P P
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30 m 5 mm	32 30 R	32 30 P
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	R At Exit Centre R	R R R P	MR MR MR MR
8	<b>MOEFA</b>		R	P MR
9	<b>Public Address System.</b>		R	P MR
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA R R	NA P P	NA MR MR
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	R 32 32	P P P	MR MR MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	30 30	P P	MR MR
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	 2850 70 m 02 180 lpm 60 m 2850 70 m R  	 2850 lpm 70 m 02 180 lpm 60 m 2850 70 m P  	 MR MR MR MR MR MR MR MR MR MR 
			NA	

14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	1,00,000	1,20,000	MR
	➤ Draw-off connection	R	P	MR
	➤ Fire service inlet	R	P	MR
	➤ Access to tank	R	P	MR
	• Overhead Tank capacity	NA	NA	NA
15	<b>Exit Signage.</b>			
		R	P	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	R	P	MR
	• Fireman's Grounding Switch	R	P	MR
	• Lift Signage	R	P	MR
17	<b>Standby power supply</b>			
		R	P	MR
18	<b>Refuge Area.</b>			
		NA		
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	R	P	MR
	• Flow Switch Panel	R	P	MR
	• PA System Panel	R	P	MR
	• Batter backup	R	P	MR
	• Building Floor Plans	R	P	MR
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>			
		NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers... *complied*

*8976/CFR/MS  
21-19*

Signature of the Inspecting Officer

Name

*Sunil Chaudhary*

Designation

*Off. C.F.O.*

*CFD. ms cell P210.*

Signature of the Inspecting Officer

Name

*Mr. SHARMA*

Designation

*ADO (C.S.)*