

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/SZ/2020/ 61

Dated: 09/03/2020

**FIRE SAFETY CERTIFICATE**

Certified that the **M/s. Grand Kitchen running at Ground Floor** of a building comprised of basement, stilt, ground plus three upper floors located at GF, 2/6, East Patel Nagar, New Delhi. The restaurant was inspected by the officer concerned of this department on 24.01.2020 in presence of Sh. Satbir Singh (G.M) and found that the owner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (restaurant) at **ground floor only** with effect from 09/03/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 09/03/2020 at New Delhi by.

(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. The Deputy Health Officer, North Delhi Municipal Corporation, Karol Bagh Zone, Anand Parbat, New Delhi- 110005.
2. The Addl. Commissioner of Police (Lic.), 1<sup>st</sup> floor, Police Station Defence Colony, New Delhi.
3. The Owner / Occupier, M/s. Grand Kitchen, GF, 2/6, East Patel Nagar, New Delhi.

## CONDITIONS

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : M/s. Grand Kitchen, GF, 2/6, East Patel Nagar, New Delhi.
2. Type of Occupancy : Assembly (Restaurant)
3. Type of Case : New Case
4. Details of previous NOC : Nil
5. Fire Safety directives letter No : N/A
6. Date of inspection : 24/01/2020
7. Name of the Inspecting Officers : Shri Rajbir Kharb, ADO(SRD)
8. Name and designation of officers from the building side : Sh. Satbir Singh, (G.M)
9. Year of Construction : 2009 - 2010
10. Applicant's letter No. : 44851-57/Addl. CP/Lic/EH(DA-X) dated, New Delhi, the 26.12.2019

The said restaurant is running at ground floor of a building comprised of basement, stilt, ground plus three upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC/BBL	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	02 nos	02 nos	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	2.0 & 1.5 mts	2.0 & 1.5 mts	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	--	-----	---
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2.0 mts.	2.0, 1.5 mts	MR
3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	• Basements (other's property)	30 a/c per hour	N/A	N/A
	• Upper floors(Restaurant-GF)	12 a/c per hour	Exhaust fan provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	08	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on G. floor (Rest.)	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/A	Provided	N/A
	• Location of Main Panel	N/A	GF	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A

8	<b>MOEFA</b>	Required	Provided	MR
---	--------------	----------	----------	----

9	<b>Public Address System.</b>	Required	Provided	MR
---	-------------------------------	----------	----------	----

10	<b>Automatic Sprinkler System.</b>			
	• Basement	N/A	N/A	N/A
	• Entire Restaurant	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A

11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	Provided (100 mm)	N/A
	• Number of hydrants per floor	N/A	Provided (01 No.)	N/A
	• Hose Box	N/A	Provided (01 No.)	N/A

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A

13	<b>Pumping Arrangements.</b>			
	• Ground Level	---	---	---
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level	-----	-----	-----
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	30 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A

15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under Delhi Fire Service Act-2007 & Rules- 2010. DFA is put up for approval & signature please.


*[Handwritten Signature]*  
3/2

Rajbir Kharb  
Asstt. Div. Officer (S.Rd)

D.O. (SW)

*[Handwritten Signature]*  
4/2/2020

DCFO (S2) Please number the file



*[Handwritten Signature]*  
5/2



*[Handwritten Signature]*  
8/2

Pls bring...