

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001


No. F6/DFS/MS/Hotel/2020/NDZI/ 147

Dated: 11/03/2020

FIRE SAFETY CERTIFICATE

Certified that **Hotel Holiday Inn located at plot no. 13-A, Distt. Centre Mayur Vihar, Delhi**, owned/occupied by M/s Hotel Holiday Inn (A unit of Eros Grand Resorts and Hotels Pvt. Ltd.) comprised of three Basement, ground plus Fourteen upper floors was granted fire safety certificate vide letter no. **F6/DFS/MS/Hotel/2017/NDZ/607 dated-28/04/17**. The Hotel building was inspected by a team of officers concerned of this department on 24/02/20 in the presence of **Sh. Vipin Kumar (Project Manager)** and found that the Hotel building have deemed complied with the fire prevention and fire safety requirements in accordance with the rules 36 unless renewed under rule 37 or sooner cancelled under rule 40 and that the building is fit for occupancy Group A-5 "Hotel Building" with effect from ....11/03/2020.... for a period of **three** years, subject to conditions printed overleaf.

Issued on .....11/03/2020..... at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service  
7/9

To,

M/s Holiday Inn ,  
Plot No. 13-A, Distt. Centre,  
Mayur Vihar, Delhi.

Copy to:-

The Joint Commissioner of Police (Lic.)  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

### CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

