

[FORM 'H']
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/Banquet/2020/ 150

Dated 12/03/2020

FIRE SAFETY CERTIFICATE

Certified that the **Celebration Banquet Hall** Located at **Basement + Ground Floor+1ST Floor only**, A-16/3, Wazirpur Industrial Area, New Delhi – 110052 in a building comprised of Basement + Ground+2 upper Floor only was issued FSC vide Letter No. F-6/DFS/MS/Banquet/2017/100 Dated 21/01/2017. The premises was re inspected by the officers concerned of this department on 28-02-2020 in the presence of Sh. Sanjeev Verma (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D (**Ground Floor+1ST Floor only**) with effect from 12/03/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/03/2020 at New Delhi by.


(Dharampal Bhardwaj)
Dy. Chief Fire Officer

Copy to: Sh.Sanjeev Verma, Celebration Banquet Hall, A-16/3, Wazirpur Industrial Area, New Delhi – 110052.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. 2nd floor shall be used for kitchen purpose only.

