

[FORM 'H']
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/Banquet/2020/ 150

Dated 12/03/2020

FIRE SAFETY CERTIFICATE

Certified that the **Celebration Banquet Hall** Located at **Basement + Ground Floor+1ST Floor only**, A-16/3, Wazirpur Industrial Area, New Delhi – 110052 in a building comprised of Basement + Ground+2 upper Floor only was issued FSC vide Letter No. F-6/DFS/MS/Banquet/2017/100 Dated 21/01/2017. The premises was re inspected by the officers concerned of this department on 28-02-2020 in the presence of Sh. Sanjeev Verma (Owner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class “ Assembly” Group D (**Ground Floor+1ST Floor only**) with effect from 12/03/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/03/2020 at New Delhi by.

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: Sh. Sanjeev Verma, Celebration Banquet Hall, A-16/3, Wazirpur Industrial Area, New Delhi – 110052.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. 2nd floor shall be used for kitchen purpose only.

INSPECTION REPORT

1. Name & address of the building: Celebration Banquet Hall Located at, Basement Ground and 1st floor at A-16/3, Wazirpur Industrial Area, New Delhi – 110052.
2. Type of Occupancy : Assembly (Basement+ Ground+1nd floor only in a building comprised of Basement+ Ground+2 Upper floors)
3. Type of Case :Renewal
4. Details of previous NOC : F6/DFS/MS/Banquet/2017/100 Dated 21/01/2017
5. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2011/43 Dated 06/01/2012
6. Date of inspection : 28-2-2020
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Sanjeev Verma (Owner)
9. Year of Construction : 1975
10. Applicant's letter No. : Nil Dated 06/02/2020

S No	Minimum standards on fire prevention and fire safety U/R 33	As Per Directive	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	9m	MR
	• Gate width	5m	5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2x1.5 m, 1x100cm	1x175cm, 1x100cm 1x150 cm provided	MR(Old Case)
	• Basements	1x1.65 m, 1x100cm	1x165cm & 1x90cm Provided	MR
	c. Protection of exits			
	• Fire check door	Required (In Basement)	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2 mtr	GF=2m, 1x100cm FF=185cm, 90cm & 100cm	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System					
	<ul style="list-style-type: none">BasementsUpper floors		Required	Provided	MR	
			Required	Provided	MR	
5.	Fire Extinguishers					
	<ul style="list-style-type: none">Total numbersTypesIS marking		10 nos. ABC & CO2 ISI marked		Provided	MR
					Provided	MR
					Provided	MR
6.	First – Aid Hose Reels					
	<ul style="list-style-type: none">Total numbers on each floorLength of hose reel hoseNozzle diameter		2	Provided	MR	
			30 m	30 mtr	MR	
			5 mm	Provided	MR	
7.	Automatic fire detection and alarming system					
	<ul style="list-style-type: none">Type of detectorsLocation of Main PanelLocation of Repeater PanelAlternate source of powerHooters’ Location		Smoke & Heat	Provided	MR	
			Ground floor	Provided	MR	
			Ground floor	Provided	MR	
			Required	Provided	MR	
			Required	Provided	MR	
8.	MOEFA		Required	Provided	MR	
9.	Public Address System		Required	Provided	MR	
10.	Automatic Sprinkler System					
	<ul style="list-style-type: none">BasementsUpper FloorSprinkler above false ceiling		Required	Provided	MR	
			NA	NA	NA	
			NA	NA	NA	
11.	Internal Hydrants					
	<ul style="list-style-type: none">Size of riser/down- comerNumber of hydrants per floorHose Box		4 inch	Provided	MR	
			2	Provided	MR	
			2	Provided	MR	
12.	Yard Hydrants					
	<ul style="list-style-type: none">Total number of HydHose Box		NA	NA	NA	
			NA	NA	NA	
13.	Pumping Arrangements					
	<ul style="list-style-type: none">Ground LevelDischarge of main pump➤ Head of main pump➤ Number of main pumps➤ Jockey pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Staring/Manual stopping➤ Pump House AccessTerrace level➤ Discharge of pump➤ Head of the pump➤ Power supply➤ Auto starting of pump					
			NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			900 lpm	Provided	MR	
			40 m	Provided	MR	
			Required	Provided	MR	
			Required	Provided	MR	
14.	Captive water Storage for fire fighting					
	<ul style="list-style-type: none">Underground tank capacity➤ Draw of connection➤ Fire service inlet➤ Access to tankOverhead Tank capacity		NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			NA	NA	NA	
			20,000 ltrs	Provided	MR	

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts(Lift run from Ground to 2 nd Floor)			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	NA	NA	NA
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F6/DFS/MS/Banquet/2017/100 Dated 21/01/2017 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name
Designation

Signature of the Inspecting Officer
Name
Designation

13/03/2020
V. K. Singh
ADDO/OPD
Note
13/03/2020
By: V. K. Singh
ADDO/OPD - F.T.
Sir FF letter is put up for sig ple
11/03/2020
not cell