

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/SZ/2020/ 64

Dated: 12/03/2020

FIRE SAFETY CERTIFICATE

Certified that the **M/s. Kadhai Tadka Restaurant (A unit of Bharat Fortune Resorts Pvt. Ltd.)** running at Ground and First Floor of a building comprised of basement, ground plus three upper floors at R-549, Shankar Road, New Rajinder Nagar, New Delhi-110060, was granted FSC vide letter No. F.6/DFS/MS/EH/2016/SZ/1191 dated 22.07.2016. The restaurant was re-inspected by the officer concerned of this department on 24/01/2020 in presence of Sh. Prakash, (Manager) and found that the owners have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class assembly (restaurant) at **Ground and First Floor only** with effect from 12/03/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 12/03/2020 at New Delhi by.



(S.S. Tuli)

Dy. Chief Fire Officer (SZ)
Delhi Fire Service

863

Copy to:-

1. Mrs. Saroj Uppal (Director), Kadai Tadka Restaurant, R-549, Shankar Road, New Rajinder Nagar, New Delhi- 110060.
2. The Deputy Health Officer, North Delhi Municipal Corporation, Karol Bagh Zone, Anand Parbat, New Delhi- 110005.
3. The Addl. Commissioner of Police (Lic), 1st Floor, Police Station Defence Colony, New Delhi.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

