

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/School/2020/SZ/ 109

Dated: 12/03/2020

FIRE SAFETY CERTIFICATE

Certified that the Oxford Angel Public School located at Khasra No. 260/3, Chhattarpur, New Delhi-110074 comprised of basement, ground plus three upper floors (but FSC issued upto 2nd floor only) was issued FSC by this department vide letter No. F6/DFS/MS/School/2017/SZ/394 dated 16/03/2017. The premises was re-inspected by the officer concerned by this department on 19/02/2020 in the presence of Mrs. Neetu Garg (Principal) of the school and found that fire prevention and fire safety requirements have deemed complied in accordance with Circular No. DOE Circular no 262-362 dated 17/01/2005 issued by Education Directorate, Govt. of NCT of Delhi, and that the premises (**basement, ground + two upper floor only**) is fit for occupancy class Education Building, Group-B as above with effect from the date of issue of this certificate for period of three years subject to compliance of conditions mentioned below.

Issued on 12/03/2020 at New Delhi by



(S.S. Tuli)

Dy. Chief Fire Officer

Tel. 011-26189168

Copy to: -

1. The Principal, Oxford Angel Public School, Kh. No. 260/3, Chhattarpur, New Delhi-110074
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Oxford Angel Public School, Kh. No. 260/3, Chhattarpur, New Delhi-110074		
2	Type of Occupancy	Educational "Group-B" (School)		
3	Building Comprised of	Basement, Ground + 03 upper floor (3 rd Floor not in use)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2017/SZ/394 dated 16/03/2017 for basement, ground plus two upper floors		
6	Fire Safety Directives Letter No	DOE Circular No-262-362 dated 17/01/2005		
7	Date of Inspection	19/02/2020		
8	Name of the Inspecting Officers	Mehmood ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Neetu Garg Principal)		
10	Year of construction	2006 & 2015		
11	Applicant letter No.	Outdoor dairy No 2257 dated 03/02/2020		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Accessible	9m	MR
	• Gate width	NA	2.10m	NA
	• Width of internal road	N/A	N/A	NA
2.	Number, width, type & arrangement of exits			
	a) Number of Staircase			
	➤ Upper floors	One	Two	MR
	➤ Basement floor	Two	Two	MR
	b) Width of Staircase			
	➤ Upper floors	1.5m	1.3m & 1m	MR
	➤ Basement floor	1.5m	1.3m & 1m	MR
	c) Protection of exits			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	01no	Provided	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	N/A	N/A	N/A
3.	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust Fan	MR
	• Upper floors	12 ACPH	NA	N/A
5.	Fire Extinguishers.			
	• Total numbers	12 Nos	12 Nos	MR
	• Types	ABC / CO2	ABC & WCO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01no	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	Automatic fire detection & alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	Required	100mm	N/A
	• Number of Hydrant per floor	N/A	One	N/A
	• Hose box.	N/A	One	N/A
12.	Yard Hydrants.			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	N/A	N/A	N/A
	➤ Head of main pump.	N/A	N/A	N/A
	➤ Number of main pumps.	N/A	N/A	N/A
	➤ Jockey Pump output.	N/A	N/A	N/A
	➤ Jockey Pump head.	N/A	N/A	N/A
	➤ Standby Pump output.	N/A	N/A	N/A
	➤ Standby pump head.	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump.	450LPM	450LPM	MR
	➤ Head of pump.	40m	40m	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	➤ Draw-off connection.	N/A	N/A	N/A
	➤ Fire Service Inlet.	N/A	N/A	N/A
	➤ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000liter	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provisions of Lifts.			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A

N/17

20.	Special Fire Protection System for the Protection of special Risk, if any.	N/A
<p>The fire protection system provided in the building/ premises were test checked at random and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, the fire safety certificate issued vide letter no. F.6/DFS/MS/School/2017/SZ/394 dated 16/03/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended</p> <p>Accordingly, DFA is put up for approval and signature please.</p>		
		<p><i>[Signature]</i> 24/2/2020 Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ)</p>

DO (SD)



[Signature]
24/02

DCFO(S2) Fresh undertaking for not using the 3rd floor may be obtained.
[Signature]
24/2

DO(SD) *[Signature]*
25/02

ADO(15)
Sir An undertaking to enclosing herewith for land department may be taken to see of 4/22.

[Signature]
3/3/2020
omur

[Signature]
DO(SD)

[Signature]
03/03

DCFO(S2) *[Signature]*
4/3

[Signature]