

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO. F6/DFS/MS/School/2020/SZ /110

Dated: 12/03/2020

FIRE SAFETY CERTIFICATE

Certified that the Indian Heights School located at Sector-23, Dwarka, New Delhi-110077, comprised of basement ground plus three upper floors was issued Fire safety certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/1318 dated 1.3.2017. The premises was re-inspected by the officer concerned of this department on 19.2.2020 in presence of Sh. Ravinder Puri & Sh. Ravi Kant (Admin.) and found that the premises have deemed complied with fire prevention and fire safety requirements in accordance with Circular no. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education Govt. of NCT of Delhi, and that the building/premises is fit for occupancy class B "Educational building" with effect from 12/03/2020 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed overleaf.

Issued on 12/03/2020 at New Delhi by


12/3
(S S Tuli)
Dy.Chief Fire Officer


Copy to:-

1. The Deputy Director (Education), Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.
2. The Principal, Indian Heights School, located at Sector-23, Dwarka, New Delhi-110077.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time. It should not bolted /locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any loss of life any property due to the non-functional of any fire safety measures, management shall be held responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

