# GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
# HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Banquet/2020/WZ/ 157 Dated: 17/03/2020

## FIRE SAFETY CERTIFICATE

The Maidens Crown Banquets (A unit of SRK Hospitality) at Plot No. B-1, Udyog Nagar Industrial Area, New Delhi-41 comprised of Basement, Ground Floor & Two Upper Floors only owned / occupied by The Maidens Crown Banquets (A unit of SRK Hospitality), has already been issued NOC / FSC by this department vide letter No. F6/DMS/MS/Banquet/2017/WZ/106 dated 23/01/2017. The premises was re-inspected by the officer concerned of this department on 05.03.2020 in the presence of Sh. Sanjay Sharma (G.M.), and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building / premises is fit for occupancy class "Assembly" (Banquet Hall) /Group 'D' with effect from ..17/03/2020...for a period of 3 (three) years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

**Issued on** 17/03/2020 **at New Delhi.**

17/3/2020

**(DHARAMPAL BHARDWAJ)**
**DY. CHIEF FIRE OFFICER.**

O/C

Copy to :-

1. Authorized Signatory, The Maidens Crown Banquets ( A unit of SRK Hospitality), Plot No. B-1, Udyog Nagar Industrial Area, New Delhi-110041.
2. Dy. Health Officer, Municipal Corporation, Rohini Zone, Sec.-5 Rohini, Delhi-110008.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The from is available on WWW.dfs.Delhigovt.nic.in

# INSPECTION REPORT

Basement + G + 2 Upper Floors

1. Name & address of the building: The Maidens Crown Banquets
( A unit of SRK Hospitality)
Plot No. B-1, Udyog Nagar Industrial Area, New Delhi-41.
2. Type of Occupancy : Assembly (Banquet Hall)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DMS/MS/Banquet/2017/WZ/106 dated 23/01/2017
5. Fire Safety directives Letter No. : NBC-IV
6. Date of inspection : 05/03/2020
7. Name of the Inspecting Officer : A.D.O. (Jwala Puri)
8. Name and designation of Officer from the building side : Sh. Sanjay Sharma (G.M.)
9. Year of Construction : 1996-Admn, Altrn.-2012
10. Applicant's letter No. : - Nil outdoor diary No. 923 dated 13/01/2020

| S No | Minimum standards on fire prevention and fire safety U/R 33 | NBC-IV Requirements | Provided at site | Remarks MR/NMR |
|---|---|---|---|---|
| 1. | Access of building | | | |
| | • Road width | 12mtr | 12mtr | MR |
| | • Gate width | 5mtr | 5mtr | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 2 | 3 | MR |
| | • Basements | 2 | 2 & 1 Ramp | MR |
| | b. Width of staircases | | | |
| | • Upper floors | 2.00 mtr | 2.00mtrx2, 1.50mtrx1 | MR |
| | • Basements | 1.50 mtr | 2.00x1, 1.50x1 & 1 Ramp of 8.80 mtr | MR |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | Required | Provided | MR |
| | d. No of continuous staircase to terrace | 1 | Provided | MR |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | 2mtr x 2 | G.F.- 6.00mtrx1, 3.50mtrx1, 1.80mtrx1,1.50mtrx1,1.20mtrx1<br>1st Floor- 2.00mtrx2,1.50mtrx1, 1.15mtrx3.<br>2nd Floor- 2.00mtrx2, 1.50mtrx1,1.00mtrx1.<br>Basment-2.00x1, 1.50x1 , 8.80 mtr (Ramp) | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | N/A | N/A | N/A |
| | • Water Curtain | N/A | N/A | N/A |
| | • Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke managements System | | | |
| | • Basements | Required | Provided | MR |
| | • Upper floors | Required | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 12 | 20 | M/R |
| | • Types | ISI marked ABC/Foam/$CO_2$ | Provided | M/R |
| | • IS marking | Required | Provided | M/R |

| | | | | |
|---|---|---|---|---|
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | 2 | 2 | MR |
| | • Length of hose reel hose | 30 Mtr. | 30 Mtr. | MR |
| | • Nozzle diameter | 5mm | 5mm | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detector | Smoke | Provided | MR |
| | • Location of Main Panel | Ground Floor | Provided | MR |
| | • Location of Repeater Panel | Each Floor | Provided | MR |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | Each Floor | Provided | MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | Required | Provided | MR |
| | • Upper Floor | Required | Provided | MR |
| | • Sprinkler above false ceiling | Required | Provided | MR |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | 150mm | 150mm | MR |
| | • Number of hydrants per floor | 2 | 2 | MR |
| | • Hose Box | 2 | 2 | MR |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | Required | Provided | MR |
| | • Hose Box | Required | Provided | MR |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | 2280LPM | 2280LPM | MR |
| | ➢ Head of main pump | 70Mtr | 70Mtr | MR |
| | ➢ Number of main pumps | 2 | 2 | MR |
| | ➢ Jockey pump out put | 180LPM | 180LPM | MR |
| | ➢ Jockey pump head | 70Mtr | 70Mtr | MR |
| | ➢ Standby Pump out put | 2280LPM | 2280LPM | MR |
| | ➢ Standby Pump Head | 70Mtr | 70Mtr | MR |
| | ➢ Auto Staring/Manual stopping | Required | Provided | MR |
| | ➢ Pump House Access | Required | Provided | MR |
| | • Terrace level | | | |
| | ➢ Discharge of pump | 900LPM | 900LPM | MR |
| | ➢ Head of the pump | 70 Mtr | 70 Mtr | MR |
| | ➢ Power supply | Required | Provided | MR |
| | ➢ Auto starting of pump | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting | | | |
| | • Under Ground Tank capacity | 1,00,000 Ltr. | 1,00,000 Ltr. | MR |
| | ➢ Draw of connection | Required | Provided | MR |
| | ➢ Fire service inlet | Required | Provided | MR |
| | ➢ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | 20,000 Ltr | 20,000 Ltr | MR |

| | | | | |
|---|---|---|---|---|
| 15 | Exit Signage | Required | Provided | M/R |
| 16. | Provision of Lifts | | | |
| | ➢ Pressurization of Lift Shaft | NR | NR | NR |
| | ➢ Pressurization of lift lobby | NR | NR | NR |
| | ➢ Communication in lift Car | Required | Provided | MR |
| | ➢ Fireman's Grounding Switch | Required | Provided | MR |
| | ➢ Lift Signage | Required | Provided | MR |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | N/A | N/A | |
| | ➢ Total area | N/A | N/A | N/A |
| | ➢ Location | N/A | N/A | N/A |
| 19. | Fire control room | | | |
| | ➢ Detector system panel | N/A | N/A | N/A |
| | ➢ Flow Switch Panel | N/A | N/A | N/A |
| | ➢ PA System Panel | N/A | N/A | N/A |
| | ➢ Battery backup | N/A | N/A | N/A |
| | ➢ Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | N/A | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DMS/MS/Banquet/2017/WZ/106 dated 23/01/2017 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO/(WD)

A K Jaiswal 11/3/2020

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

16/3/2020

Dy-FO (WZ)

16/3/2020

ADO/Rewari-F-I

F.T. letter is added for signature pl.

17/3/2020

Dy CFO/(WZ)

17/3/2020

MS/Cell