

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/Indl./2020/SZ/

189

Dated:

24/04/2020

FIRE SAFETY CERTIFICATE

Certified that M/s Cotton Clothing Corporation of India, situated at Plot no, W-8, Industrial area, Phase-II, New Delhi-110020, comprised of Basement + Ground + Mezzanine + 1 Upper floor was granted FSC by this department vide letter No. F6/DFS/MS/Industrial/SZ/2017/269 dated 27/02/2017. The building was re-inspected by officer concerned of this department on 17/03/2020 in the presence of Mr. Davender (Electrical Supervisor) and found to have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules Act-2007 & Rules- 2010 and that premises/building is fit for occupancy Group G "Industrial" wef. 24/04/2020 for a period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 24/04/2020 at New Delhi by


13/4

(S.S.Tuli)

**Dy. Chief Fire Officer
Delhi Fire Service**



Copy to: -

1. M/s Cotton Clothing Corporation of India, Plot no, W-8, Industrial area, Phase-II, New Delhi-110020
2. The executive Engineer (Bldg.)-I, SDMC, 8th floor, Civic Centre, Minto Road, New Delhi-110002.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | | | |
|-------|---|---|----------------------|----------------|
| 1 | Name & Address of the Building | M/s Cotton Clothing Corporation of India, Plot no, W-8, Industrial area, Phase-II, New Delhi-110020 | | |
| 2 | Type of Occupancy | Group-G (Industrial) | | |
| 3 | Building Comprised of | Basement + Ground + Mezzanine + 1 Upper floor | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/Industrial/SZ/2017/269 dated 27/02/2017 | | |
| 6 | Fire Safety Directives Letter No | F.6/DFS/MS/BP/2013/1365 dated 15/05/2013 | | |
| 7 | Date of Inspection | 17/03/2020 | | |
| 8 | Name of the Inspecting Officers | AVTAR SINGH, ADO (MR) | | |
| 9 | Name & Designation of Officers from the building side | Mr. Davender (Electrical Supervisor) | | |
| 10 | Year of construction | 1982 | | |
| 11 | Applicant letter No. | Outdoor diary no.3071 dated 14/02/2020 | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | BBL/NBC Requirement | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | ➤ Road width | 12 m | 12 m | MR ✓ |
| | ➤ Gate width | 4.5 m | 5 mm | MR ✓ |
| | ➤ Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | Two | Provided | MR ✓ |
| | ➤ Basement floor. | Two | Provided | MR ✓ |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.25m | 1.5 & 1.25m ✓ | MR ✓ |
| | ➤ Basement floor | 1.25m | 1.7 & 1.25m ✓ | MR ✓ |
| | c) Protection of exits | | | |
| | ➤ Fire check door | Required | Provided | MR ✓ |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | Two | Provided | MR ✓ |
| | e) Width of corridor | -NA- | -NA- | -NA- |
| | f) Door size | 1 m | 1 m (final exit) | MR ✓ |
| 3 | Compartmentation. | | | |
| | • Fire check door. | Required | Provided ✓ | MR ✓ |
| | • Sealing of electrical shafts. | Required | Provided | MR ✓ |
| | • Fire rating of shaft door. | Required | Provided ✓ | MR ✓ |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | • Basement | 30 ACPH | Exhaust Fan Provided | MR ✓ |
| | • Upper floors | 12 ACPH | Natural Ventilation | MR ✓ |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | 26 Nos | 26 nos ✓ | MR ✓ |
| | • Types | ABC /CO ₂ /W.CO ₂ | 10/06/10 ✓ | MR ✓ |
| | • ISI Marking | ISI marked | Provided ✓ | MR ✓ |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor | One | Provided | MR ✓ |
| | • Length of hose-reel hose. | 30m | Provided | MR ✓ |

| | | | | |
|-------------------|---|---------------|----------|------|
| • Nozzle Diameter | | | | |
| 7 | Automatic fire detection & alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location | Smoke & Heat | Provided | MR |
| | | Ground floor | Provided | MR |
| | | -NA- | -NA- | -NA- |
| | | Required | Provided | MR |
| | | Every floor | Provided | MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement. Ground & Above floors Sprinkler above false ceiling | Required | Provided | MR |
| | | Required | Provided | MR |
| | | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. | 100 mm | Provided | MR |
| | | One | Provided | MR |
| | | One | Provided | MR |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose box | Required | 4 nos | MR |
| | | Required | 4 nos | MR |
| 13. | Pumping arrangements. | | | |
| | • Ground Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of main pump. ➤ Head of main pump. ➤ Number of main pumps. ➤ Jockey Pump output. ➤ Jockey Pump head. ➤ Standby Pump output. ➤ Standby Pump head. ➤ Auto Starting/Manual Stopping. ➤ Pump house access | 2280 LPM | Provided | MR |
| | | 60 m | Provided | MR |
| | | Two | Provided | MR |
| | | 180 LPM | Provided | MR |
| | | 60 m | Provided | MR |
| | | 2280 LPM | Provided | MR |
| | | 60 m | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | | | | |
| | • Terrace Level | | | |
| | <ul style="list-style-type: none"> ➤ Discharge of pump. ➤ Head of pump. ➤ Power supply. ➤ Auto starting of pump. | 900 LPM | Provided | MR |
| | | 40 m | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| 14. | Captive water storage for firefighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. | 1,00,000 Ltrs | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| | <ul style="list-style-type: none"> Overhead tank capacity. | 20,000 ltrs | Provided | MR |
| | | Required | Provided | MR |
| 15. | Exit Signage. | | | |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | NA- | NA- | NA- |
| | | NA- | NA- | NA- |
| | | NA- | NA- | NA- |

N/17

| | | | | |
|-----|--|----------|---------------------------------------|------|
| 17. | Standby Power Supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | • Total area | -NA- | -NA- | -NA- |
| | • Location | -NA- | -NA- | -NA- |
| 19. | Fire Control Room. | | | |
| | • Detector System Panel. | -NA- | -NA- | -NA- |
| | • Flow Switch Panel. | -NA- | -NA- | -NA- |
| | • PA system Panel. | -NA- | -NA- | -NA- |
| | • Battery backup | -NA- | -NA- | -NA- |
| | • Building floor plan | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | Required | CO ₂ extinguisher provided | MR |

The fire protection system provided in the building was test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter no. F.6/DFS/MS/Industrial/SZ/2017/269 dated 27/02/2017 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

DFA is put up for approval & signature please.

[Signature]
26/3/2020

Signature of the Inspecting Officer

Name : Avtar Singh

Designation: ADO (M.RD)

DO (SD)

[Signature]
27/03

DeFO(s2)

[Signature]
14

DO(SD)

[Signature]
07/04

ADO(me)

FT letter is put up for sign. please

[Signature]
13/04/2020

