GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/Hospital/ 2020/W2/192 **Dated:** 29/04/2020

FIRE SAFETY CERTIFICATE

Certified that **Jaipur Golden Hospital, Sector - 03, Rohini, Delhi** Comprised of **Block A-B+G+1, Block- B&C-B+G+3, Block-D-B+G+5** owned/occupied by **Jaipur Golden Hospital** was granted FSC by this department vide letter no **F6/DFS/MS/Hospital/2017/874 Dated 19/06/2017.** The premises was re-inspected by the officer concerned of this department on **20.01.2020** in the presence of **Mr. Manoj Malik (Fire Officer)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements under rule 33 of the Delhi Fire Service Rule, 2010 and the building/ premise is fit for occupancy **class "C"** with effect from 29/04/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 29/04/2020 at New Delhi

(Atul Garg)

29/04/2020

DIRECTOR
Ph; 011-23414000

Copy to:
1.The Director, Jaipur Golden Hospital, Sector - 03, Rohini, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement and means of escape facilities shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director on Form'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K"is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Block A-B+G+1, Block- B&C-B+G+3, Block-D-B+G+5

1. Name & address of the building ; Jaipur Golden Hospital, Sector - 03, Rohini, Delhi
2. Type of Occupancy : **Hospital**
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/Hospital/2017/874 Dated 19/06/2017
5. Fire Safety directives letter No N/A
6. Date of inspection : 20.01.2020
7. Name of Inspecting Officer : Dy. CFO (WZ) , DO (NW) & ADO (Rohini) ?
8. Name and designation of officers
   From the building side : Mr. Manoj Malik (Fire Officer)
9. Year of Construction : 1990 & 1999
10. Applicant's letter No. : JGH/ADMIN/FIRE/2020/365 Dated: 03/01/2020 O.D.:230 Dated: 06/01/2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV / Rule 35(6)	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	09 mtr	> 09 mtr	M/R
	• Gate width	05 mtr	Provided	M/R
	• Width of internal road	06 mtr	06 mtr	M/R
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	07	07	MR
	• Basements	07	07	M/R
	b. Width of staircases			
	• Upper Floor	2 mtr X 3 & 4 SC 1 mtr	03 SC 2 mtr & 04 SC 1 mtr	M/R
	• Basements	2 mtr X 3 & 04 SC 1 mtr	03 SC 2 mtr & 04 SC 1 mtr	M/R
	c. Protection of exits			
	Fire check door	Required	Required	M/R
	• Pressurization	NA	Provided	NA
	d. No. of continuous staircases to terrace	03	07	M/R
	e. Width of Corridor			
	f. Door Size	2 mtr	2 mtr	M/R
3.	**Compartmentation**			
	• Fire check door	Required	Provided	M/R
	• Sealing of electrical shafts	Required	Provided	M/R
	• Fire Rating of shaft door	Required	Provided	M/R
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	**Smoke Management System**			
	• Basements	30 a/c per hour	Provided GF	M/R
	• Upper floors	12 a/c per hour	Provided GF	M/R
5.	**Fire Extinguishers**			
	• Total numbers	Water CO2 09 ltr CO2 type	188	M/R
			Yes	M/R

		Type ISI Marked			
6.	**First-Aid Hose Reels**				
	• Total numbers on each floor	5 Nos.	Provided		M/R
	• Length of hose reel hose	30 m	Provided		M/R
	• Nozzle diameter	5 mm	Provided		M/R
7.	**Automatic fire detection and alarming system**				
	• Type of detectors	Required	Provided		M/R
	• Location of Main Panel	Required	Provided		M/R
	• Location of Repeater Panel	Required	Provided		M/R
	• Alternate source of power	Required	Provided		M/R
	• Hooters' Location	Common Area	Provided		M/R
8.	MOEFA	Required	Provided		M/R
9.	**Public Address System**	Required	Provided		M/R
10.	**Automatic Sprinkler System**				
	• Basement	Required	Provided		M/R
	• Ground & Upper Floors	Required	Provided		M/R
	• Sprinkler above false ceiling	NA	NA		NA
11.	**Internal Hydrants**				
	• Size of riser/down-comer	100 mm	Provided		M/R
	• Number of hydrants per floor	05 Nos.	Provided		M/R
	• Hose Box	05 Nos.	Provided		M/R
12.	**Yard Hydrants**				
	• Total number of hydrants	Required	Provided		M/R
	• Hose Box	Required	Provided		M/R
13.	**Pumping Arrangements**				
	• Ground Level				
	➢ Discharge of main Pump	2400 LPM	Provided		M/R
	➢ Head of Main pump	70 M	Provided		M/R
	➢ Number of main pumps	2 electric 1 stand by 0 Jockey	Provided		M/R
	➢ Jockey Pump out put	180 LPM	Provided		M/R
	➢ Jockey pump head	70 M	Provided		M/R
	➢ Standby Pump out put	2400 LPM	Provided		M/R
	➢ Standby Pump Head	70 M	Provided		M/R
	➢ Auto Starting/Manual Stopping	Required	Provided		M/R
	➢ Pump House Access	Required	Provided		M/R
	• Terrace level				
	➢ Discharge of pump	NA	NA		NA
	➢ Head of the pump	NA	NA		NA
	➢ Power Supply	NA	NA		NA
	➢ Auto Starting of pump	NA	NA		NA
14.	**Captive Water Storage for fire fighting**				
	• Underground tank capacity	3,00,000 lts	3,00,000 lts		M/R
	➢ Draw-off connection	Required	Provided		M/R
	➢ Fire service inlet	Required	Provided		M/R
	➢ Access to tank	Required	Provided		M/R
	• Overhead Tank capacity	20,000 ltr	20,000 ltr		M/R
15.	**Exit Signage.**	Required	Provided		M/R
16.	**Provision of Lifts.**				
	• Pressurization of Lift Shaft	Required	Provided GF		M/R
	• Pressurization of Lift lobby	NA	Provided		M/R

	• Communication In lift Car	Required	Provided	M/R
	• Fireman's Grounding Switch	Required	Provided	M/R
	• Lift Signage	Required	Provided	M/R
17.	**Standby power supply**	Required	Provided	M/R
18.	**Refuge Area.**			
	➢ Total Area	Required	Provided	M/R
	➢ Location	4th Floor	Provided	M/R
19.	**Fire Control Room**			
	• Detector System Panel	Required	Provided	M/R
	• Flow Switch Panel	Required	Provided	M/R
	• PA System Panel	Required	Provided	M/R
	• Battery backup	Required	Provided	M/R
	• Building Floor Plans	Required	Provided	M/R
20.	**Special Fire Protection System for Protection of special Risks, if any:**		No Special Risk at Present	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F6/DFS/MS/Hospital/2017/874 Dated 19/06/2017** is for renewal under rule 35 of the Delhi Fire Service rules 2010.

24/2/20

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO(NW)

26/2/20

Dy. CFO(W2)

It is H.R. Building put up your inspection report along with ADO Rohini.

DO(NW)

8/8/2020

Sir,

i) The FSC is put up by concern nominated authority under Rule 37(2) and the team