

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No.F.6 DFS/MS/School/2020/SZ/ 171

Dated: 28/4/2020

FIRE SAFETY CERTIFICATE

Certified that the Navyug School located at First Avenue, Sarojni Nagar, New Delhi., comprised of ground plus two upper floor was issued FSC by this department vide letter No. F6/DFS/MS/School/SZ/2016/05 dated 02/01/2017. The said premises was re-inspected by officer concerned of this department on 18/03/2020 in presence of Mr. K. P. Sharma (Office Manager) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from 28/4/2020 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/4/2020 at New Delhi by



(S S Tuli)

Dy. Chief Fire Officer (SZ)
Delhi fire Service

OK

Copy to: -

1. The Principal, Navyug School, First Avenue, Sarojni Nagar, New Delhi.
2. Mr. N. K. Gaur, Asstt. Fire Officer, NDMC, Palika Kender, New Delhi-110001
3. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	Navyug School, First Avenue, Sarojni Nagar, New Delhi		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground plus Two Upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/SZ/2016/05 dated 02/01/2017		
6	Fire Safety Directives Letter No	DOE Circular 262 to 362 dated 17/01/2005		
7	Date of Inspection	18/03/2020		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. K.P. Sharma (Office Manager)		
10	Year of construction	1981		
11	Applicant letter No.	Outdoor Dairy No 28726 dated 31/12/2019		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	As Per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.	Accessible	6m	MR
	• Road width	-NA-	4m	-NA-
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase	04 No's	04 Nos up to 2 nd floor & 02 Nos up to 1 st floor	MR
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase	1.50m/0.75m	1.50m, 1.28m, 1.26m, 1.16m & up to 1 st floor 1.11m & 1.09m	MR
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits	-NA-	-NA-	-NA-
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	01 No	02Nos	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3	Compartmentation.	-NA-	-NA-	-NA-
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.	30 ACPH	-NA-	-NA-
	• Basement	12 ACPH	Natural Ventilation	MR
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.	12 Nos	20 Nos	MR
	• Total numbers	ABC / CO2	ABC & Water Co2	MR
	• Types	ISI marked	Provided	MR
	• ISI Marking	-NA-	-NA-	-NA-
6.	First Aid Hose Reels.	03 N0	Provided	MR
	• Total numbers on each floor.	30 m	Provided	MR
	• Length of hose-reel hose.	6.5 mm	Provided	MR
	• Nozzle Diameter	-NA-	-NA-	-NA-
7.	Automatic fire detection & alarming system.	-NA-	-NA-	-NA-
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-


8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	Provided	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	100 mm	100 mm	MR
	• Number of Hydrant per floor	03 nos	03 nos	MR
	• Hose box.	03 nos	03 nos	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	450 +180 LPM	450 +180 LPM	MR
	➤ Head of pump.	40 m	40 m (each)	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	5,000 liter	5,000 liter	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

2/11

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No F6/DFS/MS/School/SZ/2016/05 dated 02/01/2017 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended

Accordingly, DFA is put up for approval and signature please.


Signature of the Inspecting Officer
Name: Mehmood
Designation: ADO (SJ)

~~DO(SD)~~

~~Line~~
27/03

~~SO~~
~~ADO(SJ)~~

~~DCFO(S2)~~

~~Sign~~
25/3



~~DO(SD)~~

~~Line~~
28/03

~~ADO(SJ)~~

Sir, a DFA letter put-up for signature please

~~DCFO(S2)~~

~~Sign~~
24/4

~~Sign~~
13/4/2020
ADO(SJ)

ms well