

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No.F.6 DFS/MS/School/2020/SZ/ 171

Dated: 28/4/2020

**FIRE SAFETY CERTIFICATE**

Certified that the Navyug School located at First Avenue, Sarojni Nagar, New Delhi., comprised of ground plus two upper floor was issued FSC by this department vide letter No. F6/DFS/MS/School/SZ/2016/05 dated 02/01/2017. The said premises was re-inspected by officer concerned of this department on 18/03/2020 in presence of Mr. K. P. Sharma (Office Manager) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance in accordance with Rule 33 of Delhi Fire Service Rules 2010 and that the school building is fit for occupancy class "Educational Building" Group-B, with effect from 28/4/2020 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/4/2020 at New Delhi by



(S S Tuli)

Dy. Chief Fire Officer (SZ)  
Delhi fire Service



Copy to: -

1. The Principal, Navyug School, First Avenue, Sarojni Nagar, New Delhi.
2. Mr. N. K. Gaur, Asstt. Fire Officer, NDMC, Palika Kender, New Delhi-110001
3. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

