

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**


NO. F6/DFS/MS/School/2020/SZ/ 167

Dated: 29/4/2020

**FIRE SAFETY CERTIFICATE**

Certified that the Sachdeva Global School, located at Sector-18A, Phase-II, Dwarka, New Delhi-110075, comprised of basement, ground plus three upper floors was granted NOC by this department vide letter no. F6/DFS/MS/School/2017/SZ/371 dated 15.03.2017. The premise was re-inspected by the officer concerned of this department on 19.3.2020 in the presence of Sh. A K. Thariani (Administrative officer) and found that the premise have deemed complied with fire prevention and fire safety requirements as per Director Education Circular 262 -362 dated 17.1.2005 and that the school building is fit for occupancy class B "Educational building" with effect from ~~15.03.2017~~ 29/4/2020 for a period of **three years**, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule, 2010, printed overleaf.

Issued on .....29/4/2020..... at New Delhi by



(S. S. Tuli)

 Dy.Chief Fire Officer (SZ)



Copy to:-

1. The Director, (Education), G.N.C.T.Of Delhi, Old Secretariat, New Delhi.
2. Head of School, Sachdeva Global School, Sector-18A, Phase-II, Dwarka, New

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.
9. Basement shall be used as per BBL.

