GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2020/SZ /172 **Dated:** 29/4/2020

FIRE SAFETY CERTIFICATE

Certified that the building of **S.D.M.C. Primary School,** Partap nagar, New Delhi-110064, comprised ground plus one upper floor, owned/occupied by S.D.M.C was issued FSC by this department vide letter no. F.6/DFS/MS/School/2017/SZ/61 dated 13.02.2017. The school building was re-inspected by the officer concerned of this department on 04.03.2020 in the presence of Smt. Monica and found that S.D.M.C. Primary School have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building/ premises **(School Block Only)** is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.

Issued on.....29/4/2020.....at New Delhi.

24/4

(S.S. TULI)
Dy. CHIEF FIRE OFFICER
SOUTH ZONE

22/4/2020

Copy to:-

1. The Principal,
   S.D.M.C. Primary School,
   Partap nagar, New Delhi-110064.

2. Director of Education,
   S.D.M.C, Civic Centre,
   Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. This Fire Safety Certificate is not valid for Auditorium Block.

one upper floor But Auditorium block is not with school management.

INSPECTION REPORT

1. Name & address of the building : S.D.M.C. Primary School, Partap nagar, New Delhi-110064
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2017/SZ/61 dated 13.02.2017 (For school block)
5. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
6. Date of inspection : 04.03.2020
7. Name of Inspecting Officer : A.D.O. Sandeep Duggal
8. Name and designation of officers From the building side : Smt. Monica
9. Year of Construction : 2016
10. Applicant's letter No. : Nil dated 06.01.2020

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1.	**Access to building**			
	• Road width	Accessible	12 mtrs	M/R
	• Gate width	4.5 mtrs.	4.5 mtrs (02 no.'s)	M/R
	• Width of internal road	N/A	N/A	N/A
2.	**Number, Width, Type & Arrangement of Exits**			
	a. Number of staircases			
	• Upper Floors	02 No.'s	02 No.'s	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	150 cms	150 & 150 cms	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One	MR
	e. Width of Corridor	150 cms.	250 cms.	MR
	f. Door Size	100 cms	120 cms (double door)	MR
3.	**Compartmentation**			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	**Smoke Management System**			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural Ventilation	M/R
5.	**Fire Extinguishers**			
	• Total numbers	05 no.'s	Provided	MR
	• Types	ABC/CO_2 type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	**First-Aid Hose Reels**			
	• Total numbers on each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A

	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	**MOEFA**	N/A	N/A	N/A
9.	**Public Address System**	N/A	Provided	N/A
10.	**Automatic Sprinkler System**			
	• Basement	N/A	N/A	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	**Internal Hydrants**			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	**Yard Hydrants**			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	**Pumping Arrangements**			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey Pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby Pump out put	N/A	N/A	N/A
	➢ Standby Pump Head	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➢ Discharge of pump	N/A	N/A	N/A
	➢ Head of the pump	N/A	N/A	N/A
	➢ Power Supply	N/A	N/A	N/A
	➢ Auto Starting of pump	N/A	N/A	N/A
14.	**Captive Water Storage for fire fighting**			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	**Exit Signage.**	N/A	N/A	N/A
16.	**Provision of Lifts.**			**(No Lift)**
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	**Standby power supply**	N/A	N/A	N/A
18.	**Refuge Area.**			
	➢ Total Area	N/A	N/A	N/A

N/16

19.	**Fire Control Room**			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	**Special Fire Protection System for Protection of special Risks, if any:**	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2017/SZ/61 dated 13.02.2017 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

Note:- Auditorium block is not considered as it is not with school management.

Sandeep 16/4/2020

Signature of Inspecting Officer
Name:- Sandeep Duggal
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

16/4/2020

DIVISIONAL OFFICER Diary No. 50 Dated 16/04/20

DCFO (S2) 17/4

DFO (SW) 21/4

DELHI FIRE SERVICE Date 17/4/20 Diary No. 588 Jt. Chief Fire Officer 24/4/20

ADO (SKP)
F.T. letter is put up for signature please.
Sandeep 22/4/2020