

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/C.Hall/2020/NDZ/ 212

Dated: 19/06/2020

FIRE SAFETY CERTIFICATE

Certified that the Community Hall of Joint Forum, Vasundhara Enclave, Delhi-110096, comprised of basement and ground floor only owned/occupied by Residents Welfare Association of Vasundhara Enclave have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 10/06/2020 in the presence of Sh. J.P.Sharma (Secretary) of the Community Hall and found that the building is fit for occupancy class D 'Assembly Building' with effect from ...19/06/2020... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....19/06/2020..... at New Delhi by


(Atul Garg)

Director

Delhi Fire Service



To,

The Secretary,
Community Hall of Joint Forum,
Vasundhara Enclave, Delhi-110096.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept unlocked & free from any obstruction.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. Basement shall be used as per BBL.
6. This Fire Safety certificate cannot be treated in any case for regularizations of unauthorized construction or Alteration if any.
7. All comments/ directions of the Licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate six months prior to its expiry"

