

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/C.Hall/2020/NDZ/ 212

Dated: 19/06/2020

FIRE SAFETY CERTIFICATE

Certified that the Community Hall of Joint Forum, Vasundhara Enclave, Delhi-110096, comprised of basement and ground floor only owned/occupied by Residents Welfare Association of Vasundhara Enclave have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of this department on 10/06/2020 in the presence of Sh. J.P.Sharma (Secretary) of the Community Hall and found that the building is fit for occupancy class D 'Assembly Building' with effect from 19/06/2020 for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on 19/06/2020 at New Delhi by

(Atul Garg)
Director

Delhi Fire Service

To,

The Secretary,
Community Hall of Joint Forum,
Vasundhara Enclave, Delhi-110096.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept unlocked & free from any obstruction.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. Basement shall be used as per BBL.
6. This Fire Safety certificate cannot be treated in any case for regularizations of unauthorized construction or Alteration if any.
7. All comments/ directions of the Licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : Community Hall of Joint Forum, Vasundhara Enclave, Delhi-110096.
2. Building is comprised of : Basement & Ground floor only
3. Type of Occupancy : Assembly (Community Hall)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F6/DFS/MS/C.Hall/2019/6261 dated 21/10/19 (for B+G)
7. Date of Inspection : 10/06/2020
8. Name of the Inspecting Officers: : R.K.Yadav (ADO)
9. Name of the designation of Officer from the building side : Sh. J.P.Sharma (Secretary)
10. Year of Construction : 2012-13
11. Applicant's letter No : Nil dated 08/05/2020

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement NBC	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	24 m	MR
	Gate width	05 m	06 m	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 no.	2 no.	MR
	Basement	2 no.	2 no.	MR
	b. Width of Staircases			
	Upper Floor	1.5 m	1.5 m each	MR
	Basement	1.5 m.	1.5 m each	MR
	c. Protection of exits			
	Fire-check door	Required	provided	MR
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	1 no.	1 no.	MR
	g. Width of Corridor	N.A.	N.A.	N.A.
	h. No. of door	2 no.	3 no.	MR
	i. Door Size	2 m	2 M,1.5 M & 1.0M	MR
3	Compartmentation.			
	Fire check door	Required	provided	MR
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	Ventilated	Ventilated	MR
	Upper floor	Ventilated	Ventilated	MR
5	Fire Extinguisher			
	Total numbers	06 no.	provided	MR
	types	CO ₂ & ABC	provided	MR
	IS marking	ISI marked	provided	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	provided	MR
	Length of hose reel hose	30 m	provided	MR
	Nozzle diameter	5 mm	provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters's location	N.A.	N.A.	N.A.
8	MOEFA	Required	provided	MR
9	Public address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	Basement	Required	provided	MR
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Total no. of hydrants each floor	1 no.	1 no.	MR
	Hose Box per floor	1 no.	1 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main Pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting /Manual stopping ➤ Pump House Access Terrace Level ➤ Discharge of pump ➤ Head of the Pump ➤ Power supply ➤ Auto Starting of pump 			
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		900 LPM	provided	MR
		40 m	provided	MR
		Required	provided	MR
		Required	provided	MR
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	25,000 Liters	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/13

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The building was issued shortcomings vide letter no. F6/DPS/MS/C.Hall/2019/6261 dated 21/10/19 which is rectified. The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to grant fire safety certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name : R. K. Yadav

Designation : ADO (LN)

DOCCB on tag
 DYCCB on tag
 16/6



C.F.O.
 16/6
 16/6/20

FI PS