

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2020 / EA/92

Dated: 02/06/2020

FIRE SAFETY CERTIFICATE

Certified that the **M/s Pehalwan Vaishno Dhaba, located at ground floor , A-296/A, Pyare Lal, Kapahi Marg, Majlish Park, Delhi- 110033** in the building comprised of Ground and 02 upper floors owned/ occupied by **M/s Pehalwan Vaishno Dhaba** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 12.03.2020 in the presence of **Sh. Madan lal** and that the building/ premise is fit for occupancy Class **Assembly for ground floor only** with effect from 02/06/2020 for a period of **03 (Three) years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 02/06/2020 at New Delhi by


(Atul Garg)

Director

Ph-011-23414000

Copy to:-

1. M/s Pehalwan Vaishno Dhaba, A-296/A, GF, Pyare Lal, Kapahi Marg, Majlish Park, Delhi.
2. The Addl. CP/Lic. , 1st floor, Defence Colony, Delhi

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doiit/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
- 7 This FSC is for ground floor only.

INSPECTION REPORT

1. Name & address of the building :Pehalwan Vaishno Dhaba, A-296/A, GF, Pyare Lal, Kapahi Marg, Majlish Delhi-110088.
2. Type of Occupancy :Assembly (Ground floor only) G+02 upper floor
3. Type of Case :New Case GF- Dhaba
4. Details of previous NOC :Nil FF- Residence(Vacant)
5. Fire Safety directives letter No : NBC Part IV SF- Residence(Vacant)
6. Date of inspection :12.03.2020
7. Name of the Inspecting Officers :ADO (RN)
8. Name and designation of officers from the building side : Mr Madan Lal
9. Year of Construction : 1992
10. Applicant's letter No. : 44622/Addl.CP/Lic./EH(DA-VIII) dated 20.12.2019

	Minimum Standards on fire prevention and fire safety U/R 33	UBBL / NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6m	13.71m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
d. No. of continuous staircases to terrace	NA	NA	NA	
e. Width of Corridor	NA	NA	NA	
f. Door Size	2m & 1.50m	2.00m & 1.50m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

N/2

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	NA	NA
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	06nos	08nos	MR
	<ul style="list-style-type: none"> Types 	ABC/Co2	ABC-8 Co2-2	MR
	<ul style="list-style-type: none"> ISI marking 	Yes	Yes	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	01	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA

	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450lpm	450 lpm	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		20,000 ltr	20,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			

	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked and found some in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Rajesh Kumar
13/12/2020

Signature of the Inspecting Officer

Name: - Rajesh Kumar

Designation:- ADO/RN

20/12/2020

The requirements of fire prevention & fire safety measures shall be in conformity with 2005 circular as the year of conversion is 1992. Kindly check following requirements in conformity with 2005 circular:-

- i) width of door size.
- ii) Requirement of smoke Management System.
- iii) Requirement of Staircase up to terrace.
- iv) Capacity of terrace pump
- v) fire Service inlet
- vi) Access to overhead tank
- vii) Overhead tank Capacity.

Kindly also indicate the position of two required