

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO.F6/DFS/MS/School/2020/SZ/ 203

Dated: 23/6/2020

FIRE SAFETY CERTIFICATE

Certified that the Srilal Convent Sr. Sec. School, located at Pardhan Enclave, Baprola Vihar, New Delhi-110059, comprised of ground plus three upper floor was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2017/SZ/682 dated 12.05.2017. The said school building was re-inspected by the officer concerned of this department on 6.6.2020 in presence of Smt. Sunita (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from 23/6/2020 for a period of **three** years, in accordance with rule 36 unless renewed under rule 37 sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules, 2010 printed overleaf.

Issued on 23/6/2020 at New Delhi by



S.S Tuli

 Dy. Chief Fire Officer (SZ)



Copy to:-

1. The Director (Education) GNCT of Dehi, Old Secretariat, New Delhi-110054.
2. The Principal, Srilal Convent Sr. Sec. School, located at Pardhan Enclave, Baprola Vihar, New Delhi-110059.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time. It should not bolted /locked.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any loss of life any property due to the non-functional of any fire safety measures, management shall be held responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E letter dated 1.3.2011/letter dated 12.05.2017	Provided at site	Remarks MR / NMR
1	Name & address of the building	Srilal Convent Sr. Sec. School, Pardhan Enclae, Baprolal Vihar, New Delhi-110043		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (Ground + 3 Upper Floors)		
4	Details of previous NOC	F6/DFS/MS/School/2017/SZ/682 dated 12.05.2017		
5	Fire safety directives letter No	Directorate Of Education Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	6.06.2020		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Sunita (Principal)		
9	Year of construction	2005, 2014		
10	Applicant's letter No.	SLC/2121/2020 dated 18.5.2020 Two rooms & Varanda extended at in G+2 Proton at each floor are not in use & closed		
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs.	MR
	2) Gate width	4.5 Mtrs.	4.5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs.	1.50 Mtrs.	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	2 Nos.	2 Nos.	MR
	e. Width of corridor	1.50 Mtrs.	2 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	N/A	Natural Ventilation	MR
5	Fire Extinguishers			
	total numbers	1 No. for 300 Sq. M	15 Nos.	MR
	Types	Co2 OR ABC	CO2 & ABC	MR
	ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	One at each floor	One each floor	MR ✓
	Length of Hose reel hose	30 M	30 M	MR ✓
	Nozzle Diameter	5 mm	5 mm	MR ✓
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	Proided	N/A ✓
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	450 LPM	MR ✓
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR ✓
	c. Power supply	Required	Provided	MR ✓
	d. Auto starting of pump	Required	Provided	MR ✓
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10,000 Ltrs.	10,000 Ltrs	MR ✓
15	Exit Signage.	Required	Provided	MR ✓
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/13

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 & ABC Fire Extinguisher for electric panel & electric Meter. MR			

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required as per D.O.E circular dated 1.3.2011, renewal of FSC issued vide letter no. F6/DFS/MS/School/2017/SZ/682 dated 12.05.2017 is recommended.

Accordingly DFA is put up for approval and signature please.

Singh
8/6/20
S.P Bhardwaj
ADO (Dwarka)

DCS

g 9/6

DCS(S2)

FT Please

g
10/6/2020

g (SW)

g 7/6

g

ADO (DML)



FT is put up for signature please

g

g

Singh
10/6/20