

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/Audi/2020/SZ/ 262

Dated: 17/07/2020

FIRE SAFETY CERTIFICATE

Certified that the **Auditorium Building at Chinmaya Mission**, 89, Lodhi Road, New Delhi-110003, comprised of basement, ground plus two upper floors but Auditorium at first floor only, owned/occupied by Sri Chinmaya Mission was issued FSC by this department vide letter No. F6/DFS/MS/2017/SZ/626 dated 03/05/2017. The premise was re-inspected by the officer concerned of this department on 06/07/2020 in presence of Mr. Vinod Kumar Rawat and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group "D" Assembly** (Auditorium) as above with effect from 17/07/2020 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 as below.

Issued on 17/07/2020 at New Delhi by



(Sunil Choudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service



Copy to: -

1. Sh. Jitender Mohan Dhir (General Manager), M/s Chinmaya Mission located at 89, Lodhi Estate, New Delhi-110003
2. The Addl. Commissioner of Police (Lic.), 1st Floor, PS Defence Colony, New Delhi- 49

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non- functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of DFS Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of
6. UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/s Auditorium Building at Chinmaya Mission, 89, Lodhi Road, New Delhi-110003		
2	Type of Occupancy	Assembly, Group-D		
3	Building Comprised of	Basement, (storage & service) Ground plus Two Upper Floor (Auditorium at first floor only having 430 seats) Ground Floor-Open Hall & Second Floor- Offices and Residence of Swamiji.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2017/SZ/626 Dt. 03-05-1017		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/94/902 Dated 16/06/1994		
7	Date of Inspection	06-07-2020		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Vinod Kumar Rawat		
10	Year of construction	1996		
11	Applicant letter No.	Outdoor Diary No. 6083 dated 24-06-2020		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	9m	15 m ✓	MR
	• Gate width	5m	5m	MR
	• Width of internal road	-NA-	-NA- ✓	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	GF to FF= 03nos FF to SF=02nos	GF to FF=03nos FF to SF=02nos ✓	MR
	➤ Basement floor.	02nos	02nos	MR
	b) Width of Staircase			
	➤ Upper floors	Required	02nos=2.40m each up to SF & 1no=1.5m upto FF	MR (old case)
	➤ Basement floor	Required	1.70m & 2.40m ✓	MR (old case)
	c) Protection of exits			
	➤ Fire check door	Required	Provided at basement floor only	MR (old case)
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1.2 mtr (each)	03 exit gates at 1 st floor (1.6m, 1.6m & 1.50m) ✓	MR (old case)
3.	Compartmentation.			
	• Fire check door.	Required	Provided in basement	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors.	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	12 Nos	14 Nos ✓	MR
	• Types	ISI marked	ABC, CO ₂ & W.CO ₂	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.		01no & 02nos additional in Audi ✓	MR
	• Length of hose-reel hose.	Hose Reel	30m	MR
	• Nozzle Diameter		5mm	MR


7.	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Smoke & Heat	MR
	• Location of Main Panel	Ground Floor	Ground Floor	MR
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	Battery Backup	MR
	• Hooter's location	All Areas	All Areas	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	-NA-	Provided at stage only	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	150 mm	Provided	MR
	• Number of Hydrant per floor	01no	Provided	MR
	• Hose box.	01no	Provided	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	900 + 180 LPM	900 + 180 LPM	MR
	➤ Head of pump.	40m	40m	-NA-
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	100,000 Ltr	100,000 Ltr provided	MR
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	20, 000 Ltr	20, 000 Ltr provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

11/6/20

19.	Fire Control Room.			
	<ul style="list-style-type: none">• Detector system panel.• Flow switch panel.• PA system panel.• Battery backup.• Building floor plan.	Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.	ABC & CO ₂ Fire Extinguishers provided for electric panel		MR

The fire protection system provided in the building/ premises were checked, tested at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/Auditorium/2016/SZ/197 dated 03.02.2016, renewal under Rule 37 of the Delhi Fire Service Rules, 2010, is recommended. E26 CO 05/05/17 SW

Accordingly, DFA is put up for approval and signature please.


Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

M/s Auditorium Building at Chinmaya Mission, 89, Lodhi Estate, New Delhi-110003

DO (SD)

Line 15/07

F.T. please

DeFO (S2)

[Signature]

[Signature]

ADO (S.J.)

Sir. 4 G-1 letter put up for signature

DeFO (S2)

[Signature]

[Signature]
16/7/2020
ADO (SJ)

M. S. [Signature]