

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/Audi/2020/SZ/ 262

Dated: 17/07/2020

**FIRE SAFETY CERTIFICATE**

Certified that the **Auditorium Building at Chinmaya Mission**, 89, Lodhi Road, New Delhi-110003, comprised of basement, ground plus two upper floors but Auditorium at first floor only, owned/occupied by Sri Chinmaya Mission was issued FSC by this department vide letter No. F6/DFS/MS/2017/SZ/626 dated 03/05/2017. The premise was re-inspected by the officer concerned of this department on 06/07/2020 in presence of Mr. Vinod Kumar Rawat and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Group "D" Assembly** (Auditorium) as above with effect from 17/07/2020 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 as below.

Issued on 17/07/2020 at New Delhi by



(Sunil Choudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service



Copy to: -

1. Sh. Jitender Mohan Dhir (General Manager), M/s Chinmaya Mission located at 89, Lodhi Estate, New Delhi-110003
2. The Addl. Commissioner of Police (Lic.), 1<sup>st</sup> Floor, PS Defence Colony, New Delhi- 49

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non- functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of DFS Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of
6. UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

