

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 /DFS/MS /School/2020/ 236

Dated: 17/07/2020

FIRE SAFETY CERTIFICATE

Certified that the **M.C Co-ed. Primary School** located at **Lampur Delhi-110040**, comprised of **Ground floor only** owned/occupied by **M.C Co-ed. Primary School** was granted FSC by this department vide letter no. **No.F6/DFS/MS/School/2016/WZ/1624 dated 03.11.2016** The premises was re-inspected by the officer concerned of this department on **02.07.2020** in presence of **Smt. Anjani Chalal, Principal** and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from **17/07/2020**..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on **17/07/2020** at New Delhi by


(Dharampal Bhardwaj)
Dy.Chief Fire Officer
Ph.-011-25104544

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 54.
2. The Principal, M.C Co-ed. Primary School, Lampur, Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form “K”** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doi fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 “The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form ‘J’** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry”.

2/10
INSPECTION REPORT

*Three blocks
(G.F. only)* *11/11/20*

1. Name & address of the building : M.C Co-ed. Primary School, Lampur, Delhi-110040.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Ground floors only)
4. Details of previous NOC : F6/DFS/MS/School/2016/WZ/1624 Dated: 03.11.2016
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 02.07.2020
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers from the building side : Smt. Anjani Chalal (Principal)
9. Year of Construction : 1990
10. Applicant's letter No. : Nil Dairy No. 5695 dated: 08.06.2020

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education	Provided at site	Remarks MR/NMR	
1	Access to building				
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible	Accessible	MR	
		Accessible	Accessible	MR	
		NA	NA	NA	
2	Number, Width, Type & Arrangement of Exits				
	a. Number of staircases	Upper Floors	NA	NA	NA
		Basements	NA	NA	NA
	b. Width of staircases	Upper Floors	NA	NA	NA
		Basements	NA	NA	NA
		Protection of exits	NA	NA	NA
		Fire check door	NA	NA	NA
	d. No. of continuous staircases to terrace	Pressurization	NA	NA	NA
		No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	MR	
		1.00 m	1.00m	MR	
	3	Compartmentation.			
		<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door 	NA	NA	NA
			NA	NA	NA
NA			NA	NA	

