

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No F 6 / DFS / MS / 2020 / 234

Dated: 17/07/2020

FIRE SAFETY CERTIFICATE

Certified that the **St. Ramjas Convent School** located at **342 & 693, Bhalswa Village, Delhi-42** comprised of **Ground and 01 upper floors with hall** owned/ occupied by the **St. Ramjas Convent School** was issued fire safety certificate vide this office letter no. **F.6/DFS/MS/2017/School/WZ/140** dated **03/02/2017**. The premises was re-inspected by the officer concerned of this department on 29.06.2020 in the presence of **Smt. Saroj Yadav, Principal** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from **17/07/2020** for a period of three years, subject to compliance of the conditions mentioned below:

Issued on **17/07/2020** at New Delhi by.


(Dharmpal Bhardwaj)
Dy. Chief Fire Officer
Ph:-011-25156707

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, St. Ramjas Convent School, 342 & 693, Bhalswa Village, Delhi-110042.

Conditions for the validity of Fire Safety Certificate:

- 1 All the means of escape/entry/exit shall be kept free from any obstruction.
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of firefighting system.
- 4 The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 6 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

2/11

INSPECTION REPORT

1. Name & address of the building : St. Ramjas Convent School, 342 & 693, Bhalswa Village, Delhi-110042.
2. Type of Occupancy : Educational (G+01 upper floors with hall- **hall having 2 exits width 2 m each**)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2017/School/WZ/140 Dated: 03.02.2017
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 29/06/2020
7. Name of the Inspecting Officers : ADO (RN)
8. Name and designation of officers
from the building side : Mrs. Saroj Yadav (Principal)
9. Year of Construction : 2009
10. Applicant's letter No. : SRCS/DFS/06/2020 Dated-15.05.2020

	Minimum Standards on fire prevention and fire safety U/R 33	Circular of Director of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.30m & 1.0m	MR(Old case)
	• Basements	NA	(one iron staircase)	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	Required	02m	MR
f. Door Size	1m & hall 02 exits	1m & hall exits 02m	MR	
3	Compartmentation.			
	• Fire check door	NA	NA	NA

