GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI–110001

No. F.6/DFS/MS/EH/2020/SZ/116 Dated: 04/08/2020

FIRE SAFETY CERTIFICATE

Certified that **M/s McDonald's Family Restaurant** at (Ground, Mezzanine and first floor only) 47, Basant Lok, Vasant Vihar, New Delhi-110057 comprised of B+G+Mezz.+03 upper floors (2nd & 3rd floors are other's property) was granted FSC by this department vide letter No. F.6/DFS/MS/EH/ 2017/SZ/1571 dated 03/11/2017. The premise were re-inspected by the officer concerned of this department on 10/07/2020 in the presence of Mr. Champak Kumar (Manager) and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **"Assembly, Group-D" (Restaurant)** with effect from 04 / 08 /2020 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04 / 08 /2020 at New Delhi by

(S. S. Tuli)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Health Officer, South Zone, South Delhi Municipal Corporation, Public Health Department, Aurobindo Marg, Green Park, New Delhi–110016
2. The Manager, **M/s McDonald's Family Restaurant** at 47, Basant Lok, Vasant Vihar, New Delhi-110057.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. This Fire Safety Certificate is valid only for restaurant shop no. 125, located inside the mall.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL–2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

		(Operated By M/s Connaught Plaza Restt Pvt Ltd)		
2	Type of Occupancy	Group–D Assembly Building. (Restaurant)		
3	Building Comprised of	B+G+Mezz.+03 upper floors (2nd & 3rd floors are others property)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/EH/ 2017/SZ/1571 dated 03/11/2017		
6	Fire Safety Directives Letter No	Cir.No.F.6/DFS/EH/MS/ 2005/718 dated 04/04/2005		
7	Date of Inspection	10/07/2020		
8	Name of the Inspecting Officers	DO (SD) S K Dua		
9	Name & Designation of Officers from the building side	Mr. Champak Kumar (Manager)		
10	Year of construction	1990		
11	Applicant letter No.	Online No. 2020061105320 dated 01/07/2020		
S. No.	**Minimum standards on Fire Prevention and Fire Safety U/R 33**	**Old NOC requirements**	**Provided at Site**	**Remarks MR/NMR**
1	**Access to Building.**			
	• Road width	Required	9m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	**Number, width, type & arrangement of exits.**			
	a) Number of Staircase			
	➢ Upper floors.	02 Nos	02 Nos	MR
	➢ Basement floor.	02 Nos	02 Nos	MR
	b) Width of Staircase			
	➢ Upper floors	1.08 & 1.18m	1.08 & 1.18m	MR
	➢ Basement floor	1.08 & 1m	1.08 & 1m	MR
	c) Protection of exits			
	➢ Fire check door	N/A	N/A	N/A
	➢ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	Required	One	MR
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	N/A	N/A	N/A
3	**Compartmentation.**			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	**Smoke Management system.**			
	• Basement	30 ACPH	Exhaust Fans Provided	MR
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5	**Fire Extinguishers.**			
	• Total numbers	08 Nos	08 Nos	MR
	• Types	ABC/CO_2	ABC-05 & CO_2-03	MR
	• ISI Marking	ISI marked	Provided	MR
6	**First Aid Hose Reels.**			
	• Total numbers on each floor.	One	One	MR
	• Length of hose-reel hose.	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR

7	**Automatic fire detection & alarming system.**			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	**MOEFA**	Required	Provided	MR
9	**Public Address System**	N/A	N/A	N/A
10	**Automatic Sprinkler System**			
	• Basement	Required	Provided	M/R
	• Ground floor.	Required	Provided	M/R
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	**Internal Hydrants.**			
	• Size of Riser/Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	Required	One	MR
	• Hose box.	Required	One	MR
12	**Yard Hydrants.**			
	• Total number of hydrants.	N/A	N/A	N/A
	• Hose box.	N/A	N/A	N/A
13	**Pumping arrangements.**			
	• **Ground Level**			
	➢ Discharge of main pump.	N/A	N/A	N/A
	➢ Head of main pump.	N/A	N/A	N/A
	➢ Number of main pumps.	N/A	N/A	N/A
	➢ Jockey Pump output.	N/A	N/A	N/A
	➢ Jockey Pump head.	N/A	N/A	N/A
	➢ Standby Pump output.	N/A	N/A	N/A
	➢ Standby Pump head.	N/A	N/A	N/A
	➢ Auto Starting/Manual Stopping.	N/A	N/A	N/A
	➢ Pump house access.	N/A	N/A	N/A
	• **Terrace Level**			
	➢ Discharge of pump.	450 LPM	450 LPM	MR
	➢ Head of pump.	35m	35m	MR
	➢ Power supply.	Required	Provided	M/R
	➢ Auto starting of pump.	Required	Provided	M/R
14	**Captive water storage for fire fighting.**			
	• Underground tank capacity.	N/A	N/A	N/A
	➢ Draw-off connection.	N/A	N/A	N/A
	➢ Fire Service Inlet.	N/A	N/A	N/A
	➢ Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	5,000 Ltrs	10,000 ltr	MR
15	**Exit Signage.**	Required	Provided	MR
16	**Provision of Lifts.**			
	• Pressurization of lift shaft.	N/A	N/A	N/A
	• Pressurization of lift lobby.	N/A	N/A	N/A
	• Communication in lift car.	N/A	N/A	N/A
	• Fireman's switch.	N/A	N/A	N/A
	• Lift signage.	N/A	N/A	N/A
17	**Standby Power Supply**	Required	Provided	MR
18	**Refuge Area**			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A

19	**Fire Control Room.**			
	• Detector system panel.	N/A	N/A	N/A
	• Flow switch panel.	N/A	N/A	N/A
	• PA system panel.	N/A	N/A	N/A
	• Battery backup.	N/A	N/A	N/A
	• Building floor plan.	N/A	N/A	N/A
20	**Special Fire Protection System for the Protection of special Risk, if any.**	N/A	N/A	N/A

Renewal **M/s McDonald's Family Restaurant** at 47, Basant Lok, Vasant Vihar, New Delhi-110057.

The Fire protection systems provided in the building were checked / operated and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the FSC issued vide letter No. F.6/DFS/MS/EH/ 2017/SZ/1571 dated 03/11/2017, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

23/07

Signature of the Inspecting Officer
Name: S. K. Dua
Designation: DO (SD)

DCFO (SZ)

30/7

DELHI FIRE SERVICE
Date 30/7/20
Diary No 1140
03/8/2020
Dy. Chief Fire Officer

FT please.

DO (SD)

F.T. letter is put up for sig. pl.

31/07

DCFO (SZ)

3/8/2020

MS cell