

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2020/ 283

Dated: 14/08/2020

FIRE SAFETY CERTIFICATE

Certified that A-One International Public School, B-Block, Inder Enclave Phase-I, Delhi-110086, comprised of Basement + Ground + Three upper floors (school is running at basement + ground & first floor only) owned/occupied by A-One International Public School was granted fire safety certificate vide department letter no. F6/DFS/MS/2017/School/WZ/143 dated 03.02.2017, have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 31.07.2020 in the presence of Mr. Dalbir (Manager) and that the building/premises is fit for occupancy class "Group B Educational" for basement + ground & first floor only with effect from 14/08/2020 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 14/08/2020 at New Delhi by

(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01125156707

Copy to:

1. The Principal, A-One International Public School, B-Block, Inder Enclave Phase-I, Delhi-110086.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

A-One International Public School, B-Block, Inder Enclave, Phase-I, Delhi-110086

1. Name & address of the building : A-One International Public School, B-Block, Indir Enclave Phase-I, Delhi-110086.
2. Type of Occupancy : Educational (B + G + 03 Upper floor) **School is running B+G+01**
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/2017/School/WZ/143 dated 03.02.2017(B + G + 01)
5. Fire Safety directives letter No : N/A
6. Date of inspection : 31.007.2020
7. Name of Inspecting Officer : ADO (Rohini)
8. Name and designation of officers
From the building side : Sh. Dalbir (Manager)
9. Year of Construction : 2010 & 2014
10. Applicant's letter No. : nil dated 15.06.2020, O.D 5877 dated 16.06.2020

Plot area:4100 Sq m		Covered area:2974.93 Sq m		No. of class rooms-47	
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR	
1.	Access to building				
	• Road width	Accessible	12 mtr	MR	
	• Gate width	Accessible	5.0 mtr	M.R	
	• Width of internal road	05 mtr	06 mtr	MR	
2.	Number, Width, Type & Arrangement of Exits				
	a. Number of staircases	NA	NA	NA	
	• Upper Floors	02	02	MR	
	• Basements	02	02	MR	
	b. Width of staircases	1.50 mtr	1.25 & 1.50 mtr	MR (Old Case)	
	• Upper Floor	1.50 mtr	1.25 & 1.50 mtr	MR (Old Case)	
	• Basements	NA	NA	NA	
	c. Protection of exits	NA	NA	NA	
	Fire check door	NA	NA	NA	
	• Pressurization	NA	NA	NA	
	d. No. of continuous staircases to terrace	02	02	MR	
	e. Width of Corridor	Required	2.80 mtr	MR	
	f. Door Size	1 mtr	1.05 mtr	MR	
3.	Compartmentation				
	• Fire check door	NA	NA	NA	
	• Sealing of electrical shafts	NA	NA	NA	
	• Fire Rating of shaft door	NA	NA	NA	
	• Water Curtain	NA	NA	NA	
	• Fire Dampers	NA	NA	NA	
4.	Smoke Management System				
	• Basements	30 a/c per hour	NA	NA	
	• Upper floors	12 a/c per hour	NA	NA	
5.	Fire Extinguishers				
	• Total numbers	12 No's	12 No's	MR	
	• Types	ABC/CO2	ABC 12	MR	

	• IS marking			
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel		NA	NA
	• Location of Repeater Panel		NA	NA
	• Alternate source of power		NA	NA
	• Hooters' Location		NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground & Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltr	15,000 ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

N-20

17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked at random and found some shortcomings.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2017/School/WZ/143 dated 03.02.2017 is recommended for renewal under rule 35 of the Delhi Fire Service rules 2010

Ajay
4/8/xx
Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

Anilash
6/8/xx
A.K. MALIK

Ajay
6/8/xx

ADO/Rohini - FT. *7/8/xx*

FT letter is put up for kind perusal and signature please.

Ajay
11/8/xx