

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2020/ 280

Dated: 14/08/2020

FIRE SAFETY CERTIFICATE

Certified that the Global Demos Unity School, D-111/1, Rama Vihar, Modh. Pur Majri, Delhi-110081 comprised of Ground + One Upper Floor owned/ occupied by Global Demos Unity School have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 28.07.2020 in the presence of Mr. Harish Kumar (Owner) and that the building/ premise is fit for occupancy Group B Educational with effect from 14/08/2020 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 14/08/2020 at New Delhi by

(Atul Garg)

DIRECTOR

Ph; 011-23414000

Copy to:

1. The Principal, Global Demos Unity School, D-111/1, Rama Vihar, Modh. Pur Majri, Delhi-110081.
2. The Director of Education, Old Secretariat, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

1. Name & address of the building : Global Demos Unity School, D-111/1, Rama Vihar, Modh. Pur Majri, Delhi-110081.
2. Type of Occupancy : Educational
3. Type of Case : **New Case** (Gr.+ One Upper Floor)
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 28.07.2020
7. Name of the Inspecting Officers : ADO (Rohini)
8. Name and designation of officers from the building side : Mr. Harish Kumar (Owner)
9. Year of Construction : 2013
10. Applicant's letter No. : Online application no. nil dated 14.07.2020
- Plot area-1960 sq yard Covered area: 724sq yard No. of class rooms-12

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	06 mtr	M/R
	• Gate width	Accessible	Accessible	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	02	03	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases	N/A	N/A	N/A
	• Upper Floors	1.50 mtr	2 X 1.50m & 1.25m	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 mtr	1.0 mtr	M/R
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A


Fire Extinguishers					
	• Total numbers	04 ABC	12	MR	
	• Types	ISI marked	ABC	MR	
	• IS marking	Yes	Yes	MR	
6	First-Aid Hose Reels.				
	• Total numbers on each floor	30 m	N/A	N/A	
	• Length of hose reel hose	5 mm	N/A	N/A	
	• Nozzle diameter		N/A	N/A	
7	Automatic fire detection and alarming system.				
	• Type of detectors	N/A	N/A	N/A	
	• Location of Main Panel	N/A	N/A	N/A	
	• Location of Repeater Panel	N/A	N/A	N/A	
	• Alternate source of power	N/A	N/A	N/A	
	• Hooters' Location	N/A	N/A	N/A	
8	MOEFA	N/A	N/A	N/A	
9	Public Address System.	N/A	N/A	N/A	
10	Automatic Sprinkler System.				
	• Basement	N/A	N/A	N/A	
	• Upper Floor	N/A	N/A	N/A	
	• Sprinkler above false ceiling	N/A	N/A	N/A	
11	Internal Hydrants				
	• Size of riser/down-comer	N/A	N/A	N/A	
	• Number of hydrants per floor	N/A	N/A	N/A	
	• Hose Box	N/A	N/A	N/A	
12	Yard Hydrants.				
	• Total number of hydrants	N/A	N/A	N/A	
	• Hose Box	N/A	N/A	N/A	
13	Pumping Arrangements.				
	• Ground Level				
	➤ Discharge of main Pump	N/A	N/A	N/A	
	➤ Head of Main pump	N/A	N/A	N/A	
	➤ Number of main pumps	N/A	N/A	N/A	
	➤ Jockey Pump out put	N/A	N/A	N/A	
	➤ Jockey pump head	N/A	N/A	N/A	
	➤ Standby Pump out put	N/A	N/A	N/A	
	➤ Standby Pump Head	N/A	N/A	N/A	
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A	
	➤ Pump House Access	N/A	N/A	N/A	
	• Terrace level	N/A	N/A	N/A	
	➤ Discharge of pump	N/A	N/A	N/A	
	➤ Head of the pump	N/A	N/A	N/A	
	➤ Power Supply	N/A	N/A	N/A	

Water Storage for fire fighting.

	Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010/ issue shortcoming as noted at serial no.....nil...



DO(NW)

A.K. Malik
3/8/20
A.K. MALIK

DO(NW)

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

Amc
31/7/20

4/8/20

A. Malik